

Appendix B. Florida Facilities Exceeding their Clean Water Act Permits at Least Once between January 2005 - December 2005

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
FLO000035	E I DUPONT DE NEMOURS - HIGHLA	CLAY	BOGGY BRANCH	IRON, TOTAL RECOVERABLE	MG/L	MONTHLY AVERAGE	8/31/2005	21
FLO000035	E I DUPONT DE NEMOURS - HIGHLA	CLAY	BOGGY BRANCH	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	8/31/2005	70
FLO000035	E I DUPONT DE NEMOURS - HIGHLA	CLAY	BOGGY BRANCH	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	9/30/2005	50
FLO000035	E I DUPONT DE NEMOURS - HIGHLA	CLAY	BOGGY BRANCH	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	10/31/2005	20
FLO000035	E I DUPONT DE NEMOURS - HIGHLA	CLAY	BOGGY BRANCH	NOEL STATRE 7DAY CHR PIMEPFALES	PERCENT	MINIMUM	4/30/2005	*
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	4/30/2005	5
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	5/31/2005	9
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	6/30/2005	14
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	DAILY MAXIMUM	7/31/2005	7
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	7/31/2005	16
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	8/31/2005	8
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	DAILY MAXIMUM	12/31/2005	9
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	6/30/2005	10
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	6/30/2005	10
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	7/31/2005	40
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	8/31/2005	20
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	10/31/2005	90
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	7/31/2005	*
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	8/31/2005	*
FLO000051	E I DUPONT DE NEMOURS - TRAILR	BRADFORD	ALLIGATOR CREEK	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	9/30/2005	*
FLO000159	PROGRESS ENERGY CRYSTAL RIVER	CITRUS	GULF OF MEXICO	OIL & GREASE	MG/L	DAILY MAXIMUM	12/31/2005	221
FLO000230	IMC-AGRICO CO - NORALYN/PHO.	POLK	PEACE RV	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	5/31/2005	7
FLO000230	IMC-AGRICO CO - NORALYN/PHO.	POLK	PEACE RV	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	10/31/2005	3
FLO000230	IMC-AGRICO CO - NORALYN/PHO.	POLK	PEACE RV	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	10/31/2005	51
FLO000230	IMC-AGRICO CO - NORALYN/PHO.	POLK	PEACE RV	PHOSPHORUS, TOTAL	MG/L	DAILY MAXIMUM	10/31/2005	10
FLO000230	IMC-AGRICO CO - NORALYN/PHO.	POLK	PEACE RV	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	10/31/2005	32
FLO000230	IMC-AGRICO CO - NORALYN/PHO.	POLK	PEACE RV	PHOSPHORUS, TOTAL	MG/L	DAILY MAXIMUM	10/31/2005	33
FLO000230	IMC-AGRICO CO - NORALYN/PHO.	POLK	PEACE RV	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	10/31/2005	99
FLO000230	IMC-AGRICO CO - NORALYN/PHO.	POLK	PEACE RV	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	11/30/2005	7
FLO000230	IMC-AGRICO CO - NORALYN/PHO.	POLK	PEACE RV	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	12/31/2005	6
FLO000256	IMC-AGRICO CO - KINGSFORD	POLK	LAKE BR	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	4/30/2005	19

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
FLO000256	IMC-AGRICO CO - KINGSFORD	POLK	LAKE BR	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	5/31/2005	62
FLO000256	IMC-AGRICO CO - KINGSFORD	POLK	LAKE BR	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	10/31/2005	6
FLO000256	IMC-AGRICO CO - KINGSFORD	POLK	LAKE BR	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	11/30/2005	21
FLO000256	IMC-AGRICO CO - KINGSFORD	POLK	LAKE BR	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	12/31/2005	109
FLO000256	IMC-AGRICO CO - KINGSFORD	POLK	LAKE BR	PHOSPHORUS, TOTAL	MG/L	DAILY MAXIMUM	10/31/2005	6
FLO000256	IMC-AGRICO CO - KINGSFORD	POLK	LAKE BR	SOLIDS, FIXED SUSPENDED	MG/L	MONTHLY AVERAGE	10/31/2005	70
FLO000256	IMC-AGRICO CO - KINGSFORD	POLK	LAKE BR	SOLIDS, FIXED SUSPENDED	MG/L	DAILY MAXIMUM	10/31/2005	133
FLO000256	IMC-AGRICO CO - KINGSFORD	POLK	LAKE BR	SOLIDS, TOTAL SUSPENDED	MG/L	DAILY MAXIMUM	10/31/2005	8
FLO000264	IMC-AGRICO CO - PORT SUTTON	HILLSBOROUGH	HILLSBOROUGH BAY	PH	SU	DAILY MAXIMUM	5/31/2005	10
FLO000477	THE MINUTE MAID COMPANY	PINELLAS	ST JOSEPH SOUND	SOLIDS, TOTAL SUSPENDED	MG/L	MONTHLY AVERAGE	1/31/2005	44
FLO000477	THE MINUTE MAID COMPANY	PINELLAS	ST JOSEPH SOUND	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	2/28/2005	45
FLO000477	THE MINUTE MAID COMPANY	PINELLAS	ST JOSEPH SOUND	SOLIDS, TOTAL SUSPENDED	MG/L	MONTHLY AVERAGE	2/28/2005	90
FLO000485	JDR UTILITIES, INC.	PASCO	LARKIN CANAL	AMMONIA, UNIONIZED	MG/L	DAILY MAXIMUM	10/31/2005	1900
FLO000485	JDR UTILITIES, INC.	PASCO	LARKIN CANAL	AMMONIA, UNIONIZED	MG/L	DAILY MAXIMUM	11/30/2005	89
FLO000485	JDR UTILITIES, INC.	PASCO	LARKIN CANAL	BOD, 5 DAY (20 DEG. C)	MG/L	DAILY MAXIMUM	7/31/2005	84
FLO000485	JDR UTILITIES, INC.	PASCO	LARKIN CANAL	BOD, 5 DAY (20 DEG. C)	MG/L	MONTHLY AVERAGE	9/30/2005	7
FLO000485	JDR UTILITIES, INC.	PASCO	LARKIN CANAL	BOD, 5 DAY (20 DEG. C)	MG/L	DAILY MAXIMUM	9/30/2005	126
FLO000485	JDR UTILITIES, INC.	PASCO	LARKIN CANAL	BOD, 5 DAY (20 DEG. C)	MG/L	MONTHLY AVERAGE	10/31/2005	132
FLO000485	JDR UTILITIES, INC.	PASCO	LARKIN CANAL	BOD, 5 DAY (20 DEG. C)	MG/L	DAILY MAXIMUM	10/31/2005	363
FLO000485	JDR UTILITIES, INC.	PASCO	LARKIN CANAL	BOD, 5 DAY (20 DEG. C)	MG/L	MONTHLY AVERAGE	11/30/2005	33
FLO000485	JDR UTILITIES, INC.	PASCO	LARKIN CANAL	BOD, 5 DAY (20 DEG. C)	MG/L	DAILY MAXIMUM	11/30/2005	242
FLO000485	JDR UTILITIES, INC.	PASCO	LARKIN CANAL	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	9/30/2005	10
FLO000523	CF INDUSTRIES - BARTOW PHOS.	POLK	ALAFIA RV	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	9/30/2005	14
FLO000655	PCS PHOSPHATE-WHITE SPRINGS-	HAMILTON	SWIFT CREEK AND HUNTERS CREEK	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	1/31/2005	*
FLO000655	PCS PHOSPHATE-WHITE SPRINGS-	HAMILTON	SWIFT CREEK AND HUNTERS CREEK	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	12/31/2005	*
FLO000680	ORLANDO UTIL COM-INDIAN RV STM	BREVARD	INDIAN RV	OIL & GREASE	MG/L	MAXIMUM DAILY AVERAGE	8/31/2005	92
FLO000680	ORLANDO UTIL COM-INDIAN RV STM	BREVARD	INDIAN RV	PH	SU	MAXIMUM DAILY AVERAGE	9/30/2005	3
FLO000680	ORLANDO UTIL COM-INDIAN RV STM	BREVARD	INDIAN RV	PH	SU	MAXIMUM DAILY AVERAGE	10/31/2005	1
FLO000761	RIVERVIEW CHEMICAL COMPLEX	HILLSBOROUGH	HILLSBOROUGH BAY	FLUORIDE, TOTAL	MG/L	MAXIMUM	10/31/2005	55
FLO000761	RIVERVIEW CHEMICAL COMPLEX	HILLSBOROUGH	HILLSBOROUGH BAY	LC50 STATRE 96HR ACU CERIODAPHNIA	PERCENT	MINIMUM	5/31/2005	*
FLO000761	RIVERVIEW CHEMICAL COMPLEX	HILLSBOROUGH	HILLSBOROUGH BAY	OIL & GREASE	MG/L	MAXIMUM	10/31/2005	100
FLO000761	RIVERVIEW CHEMICAL COMPLEX	HILLSBOROUGH	HILLSBOROUGH BAY	PHOSPHORUS, TOTAL	LBS/DAY	MONTHLY AVERAGE	7/31/2005	19
FLO000817	TAMPA ELEC-BIG BEND STEAM	HILLSBOROUGH	HILLSBOROUGH BAY	SOLIDS, TOTAL SUSPENDED	MG/L	INSTANTANEOUS MAXIMUM	6/30/2005	10

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
FLO000817	TAMPA ELEC-BIG BEND STEAM	HILLSBOROUGH	HILLSBOROUGH BAY	SOLIDS, TOTAL SUSPENDED	MG/L	INSTANTANEOUS MAXIMUM	12/31/2005	640
FLO000922	USN MAYPORT NAVAL STATION WWTF	DUVAL	SAINT JOHNS RIVER	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	10/31/2005	60
FLO000922	USN MAYPORT NAVAL STATION WWTF	DUVAL	SAINT JOHNS RIVER	OIL & GREASE	MG/L	MAXIMUM	2/28/2005	26
FLO000922	USN MAYPORT NAVAL STATION WWTF	DUVAL	SAINT JOHNS RIVER	OIL & GREASE	MG/L	MAXIMUM	3/31/2005	24
FLO000922	USN MAYPORT NAVAL STATION WWTF	DUVAL	SAINT JOHNS RIVER	OIL & GREASE	MG/L	MAXIMUM	6/30/2005	100
FLO000922	USN MAYPORT NAVAL STATION WWTF	DUVAL	SAINT JOHNS RIVER	SURFACTANTS (MBAS)	MG/L	MAXIMUM	3/31/2005	6
FLO000922	USN MAYPORT NAVAL STATION WWTF	DUVAL	SAINT JOHNS RIVER	SURFACTANTS (MBAS)	MG/L	MAXIMUM	4/30/2005	44
FLO000922	USN MAYPORT NAVAL STATION WWTF	DUVAL	SAINT JOHNS RIVER	SURFACTANTS (MBAS)	MG/L	MAXIMUM	5/31/2005	8
FLO000957	USN NAS JACKSONVILLE STP	DUVAL	ST JOHNS RV	PH	SU	MINIMUM	6/30/2005	5
FLO000957	USN NAS JACKSONVILLE STP	DUVAL	ST JOHNS RV	SURFACTANTS (MBAS)	MG/L	MAXIMUM	4/30/2005	30
FLO001104	JEFFERSON SMURFIT FERNANDINA	NASSAU	AMELIA RV	BOD, 5 DAY (20 DEG. C)	LBS/DAY	MONTHLY AVERAGE	3/31/2005	87
FLO001104	JEFFERSON SMURFIT FERNANDINA	NASSAU	AMELIA RV	BOD, 5 DAY (20 DEG. C)	LBS/DAY	DAILY MAXIMUM	3/31/2005	369
FLO001104	JEFFERSON SMURFIT FERNANDINA	NASSAU	AMELIA RV	PH	SU	DAILY MAXIMUM	3/31/2005	2
FLO001198	FORT MEADE MINE	POLK	WHIDDEN CR	SOLIDS, FIXED SUSPENDED	MG/L	DAILY MAXIMUM	2/28/2005	54
FLO001198	FORT MEADE MINE	POLK	WHIDDEN CR	SOLIDS, TOTAL SUSPENDED	MG/L	MONTHLY AVERAGE	2/28/2005	12
FLO001198	FORT MEADE MINE	POLK	WHIDDEN CR	SOLIDS, TOTAL SUSPENDED	MG/L	DAILY MAXIMUM	2/28/2005	95
FLO001198	FORT MEADE MINE	POLK	WHIDDEN CR	SOLIDS, TOTAL SUSPENDED	MG/L	DAILY MAXIMUM	3/31/2005	5
FLO001465	GOLDKIST INC	SUWANNEE	SUWANNEE RIVER	LC50 STATRE 96HR ACU CERIODAPHRINA	PERCENT	MINIMUM	12/31/2005	*
FLO001465	GOLDKIST INC	SUWANNEE	SUWANNEE RIVER	OIL & GREASE	MG/L	DAILY MAXIMUM	1/31/2005	14
FLO001465	GOLDKIST INC	SUWANNEE	SUWANNEE RIVER	OIL & GREASE	MG/L	DAILY MAXIMUM	6/30/2005	84
FLO001465	GOLDKIST INC	SUWANNEE	SUWANNEE RIVER	OIL & GREASE	MG/L	DAILY MAXIMUM	9/30/2005	34
FLO001538	FL PWR & LT-PT EVERGLADE STEAM	BROWARD	INTRACOASTAL WATERWAY	COPPER, TOTAL RECOVERABLE	UG/L	INSTANTANEOUS MAXIMUM	6/30/2005	332
FLO001538	FL PWR & LT-PT EVERGLADE STEAM	BROWARD	INTRACOASTAL WATERWAY	NICKEL, TOTAL RECOVERABLE	UG/L	INSTANTANEOUS MAXIMUM	6/30/2005	273
FLO001546	FL PWR & LT-RIVIERA STEAM	PALM BEACH	LAKE WORTH	OXIDANTS, TOTAL RESIDUAL	MG/L	INSTANTANEOUS MAXIMUM	2/28/2005	60
FLO001546	FL PWR & LT-RIVIERA STEAM	PALM BEACH	LAKE WORTH	OXIDANTS, TOTAL RESIDUAL	MG/L	INSTANTANEOUS MAXIMUM	5/31/2005	30
FLO001546	FL PWR & LT-RIVIERA STEAM	PALM BEACH	LAKE WORTH	OXIDANTS, TOTAL RESIDUAL	MG/L	INSTANTANEOUS MAXIMUM	6/30/2005	10
FLO001589	BARTOW PHOSPHATE COMPLEX	POLK	ALAFIA RV	AMMONIA, UNIONIZED	MG/L	DAILY MAXIMUM	10/31/2005	50
FLO001589	BARTOW PHOSPHATE COMPLEX	POLK	ALAFIA RV	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	10/31/2005	10
FLO001961	US AGRI-CHEMICALS BARTOW PLANT	POLK	PEACE RV	PH	SU	DAILY MINIMUM	10/31/2005	9
FLO002275	GULF PWR CO-CRIST STEAM	ESCAMBIA	ESCAMBIA RV	IRON, TOTAL RECOVERABLE	MG/L	MAXIMUM MONTHLY AVERAGE	5/31/2005	160
FLO002275	GULF PWR CO-CRIST STEAM	ESCAMBIA	ESCAMBIA RV	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM MONTHLY AVERAGE	3/31/2005	2
FLO002275	GULF PWR CO-CRIST STEAM	ESCAMBIA	ESCAMBIA RV	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM DAILY AVERAGE	3/31/2005	69
FLO002275	GULF PWR CO-CRIST STEAM	ESCAMBIA	ESCAMBIA RV	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM MONTHLY AVERAGE	4/30/2005	14

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0002275	GULF PWR CO-CRIST STEAM	ESCAMBIA	ESCAMBIA RV	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM DAILY AVERAGE	4/30/2005	54
F0002488	SOLUTION INC.	ESCAMBIA	ESCAMBIA RV	PH	SU	MAXIMUM	4/30/2005	11
F0002488	SOLUTION INC.	ESCAMBIA	ESCAMBIA RV	PH	SU	MAXIMUM	6/30/2005	1
F0002500	USN NAS PENSACOLA STP	ESCAMBIA	PENSACOLA BAY	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	ANNUAL AVERAGE	7/30/2005	25
F0002500	USN NAS PENSACOLA STP	ESCAMBIA	PENSACOLA BAY	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	2/28/2005	15
F0002500	USN NAS PENSACOLA STP	ESCAMBIA	PENSACOLA BAY	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	3/31/2005	27
F0002518	ST. MARKS POWDER, INC.	WAKULLA	BIG BOGGY BR	NITROGEN, TOTAL	LBS/YR	MONTHLY TOTAL	1/31/2005	46
F0002518	ST. MARKS POWDER, INC.	WAKULLA	BIG BOGGY BR	NITROGEN, TOTAL	LBS/DAY	ANNUAL AVERAGE	1/31/2005	5073
F0002518	ST. MARKS POWDER, INC.	WAKULLA	BIG BOGGY BR	NITROGEN, TOTAL	LBS/DAY	DAILY MAXIMUM	3/31/2005	42
F0002518	ST. MARKS POWDER, INC.	WAKULLA	BIG BOGGY BR	PHOSPHORUS, TOTAL	LBS/DAY	DAILY MAXIMUM	3/31/2005	474
F0002518	ST. MARKS POWDER, INC.	WAKULLA	BIG BOGGY BR	PHOSPHORUS, TOTAL	LBS/DAY	MONTHLY AVERAGE	3/31/2005	518
F0002526	INTERNATIONAL PAPER COMPANY	ESCAMBIA	ELEVENMILE CREEK	BOD, 5 DAY (20 DEG. C)	LBS/DAY	DAILY MAXIMUM	3/31/2005	2
F0002526	INTERNATIONAL PAPER COMPANY	ESCAMBIA	ELEVENMILE CREEK	BOD, 5 DAY (20 DEG. C)	LBS/DAY	DAILY MAXIMUM	4/30/2005	106
F0003051	FL DISTILLERS CO.AUBURNDALE	POLK	LAKE LENA RUN	NITROGEN, AMMONIA, TOTAL UNIONIZED	MG/L	DAILY MAXIMUM	7/31/2005	150
F0002109	WINTER GARDEN STP	ORANGE	LAKE APOPKA	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	8/31/2005	3
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	1/31/2005	37
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MONTHLY AVERAGE	2/28/2005	23
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	2/28/2005	23
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	8/31/2005	31
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	CYANIDE, TOTAL	UG/L	MAXIMUM	10/31/2005	467
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	CYANIDE, TOTAL	UG/L	MAXIMUM	11/30/2005	6
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	1/31/2005	3
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	1/31/2005	136
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	2/28/2005	3
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	2/28/2005	132
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	3/31/2005	3
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	3/31/2005	141
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	4/30/2005	141
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	5/31/2005	141
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	6/30/2005	203
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	7/31/2005	242
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	8/31/2005	219
F0002141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	9/30/2005	146

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	10/31/2005	157
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	11/30/2005	199
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	12/31/2005	216
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	NITROGEN, AMMONIA TOTAL	MG/L	WEEKLY AVERAGE	1/31/2005	24
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	NITROGEN, AMMONIA TOTAL	MG/L	MONTHLY AVERAGE	1/31/2005	40
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	NITROGEN, AMMONIA TOTAL	MG/L	MAXIMUM	1/31/2005	47
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	NITROGEN, TOTAL	MG/L	MAXIMUM	10/31/2005	33
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	6/30/2005	1400
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	7/31/2005	200
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	8/31/2005	1800
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	9/30/2005	1400
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	10/31/2005	1300
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	11/30/2005	1600
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	12/31/2005	4100
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	1/31/2005	82
FLO020141	SANFORD-MUNICIPAL WTP	SEMINOLE	LAKE MONROE	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	6/30/2005	35
FLO020231	JAX BEACH STP	DUVAL	CRADLE CREEK AND ST JOHNS RV	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	5/31/2005	20
FLO020303	DELAND WTP	VOLUSIA	ST JOHNS RV	PHOSPHORUS, TOTAL	MG/L	WEEKLY AVERAGE	7/31/2005	13
FLO020401	PALMETTO STP	MANATEE	TERRA CEIA BAY	NICKEL, TOTAL RECOVERABLE	UG/L	MAXIMUM	8/31/2005	228
FLO020401	PALMETTO STP	MANATEE	TERRA CEIA BAY	NICKEL, TOTAL RECOVERABLE	UG/L	MAXIMUM	12/31/2005	26
FLO020401	PALMETTO STP	MANATEE	TERRA CEIA BAY	NOEL STATRE 7DAY CHR MENIDIA	PERCENT	MINIMUM	4/30/2005	*
FLO020401	PALMETTO STP	MANATEE	TERRA CEIA BAY	NOEL STATRE 7DAY CHR MYSID. BAHIA	PERCENT	MINIMUM	4/30/2005	*
FLO020401	PALMETTO STP	MANATEE	TERRA CEIA BAY	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	4/30/2005	10
FLO020401	PALMETTO STP	MANATEE	TERRA CEIA BAY	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	4/30/2005	20
FLO020401	PALMETTO STP	MANATEE	TERRA CEIA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	5/31/2005	2
FLO020427	NEPTUNE BEACH WWTP	DUVAL	SAINT JOHNS RIVER	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	2/28/2005	12
FLO020451	PANAMA CITY-ST ANDREWS STP	BAY	ST ANDREWS BAY	COLIFORM, FECAL GENERAL	#/100ML	MONTHLY MEDIAN	7/31/2005	636
FLO020451	PANAMA CITY-ST ANDREWS STP	BAY	ST ANDREWS BAY	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	7/31/2005	2226
FLO020451	PANAMA CITY-ST ANDREWS STP	BAY	ST ANDREWS BAY	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	12/31/2005	*
FLO020532	ORMOND BEACH STP	VOLUSIA	HALIFAX RV	DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	1/31/2005	100
FLO020532	ORMOND BEACH STP	VOLUSIA	HALIFAX RV	DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	10/31/2005	4
FLO020532	ORMOND BEACH STP	VOLUSIA	HALIFAX RV	DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	11/30/2005	3
FLO020532	ORMOND BEACH STP	VOLUSIA	HALIFAX RV	DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	12/31/2005	4

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0020532	ORMOND BEACH STP	VOLUSIA	HALIFAX RV	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	4/30/2005	45
F0020532	ORMOND BEACH STP	VOLUSIA	HALIFAX RV	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	7/31/2005	10
F0020541	CAPE CANAVERAL	BREVARD	BANANA RV	NITROGEN, TOTAL	MG/L	MAXIMUM	2/28/2005	51
F0020541	CAPE CANAVERAL	BREVARD	BANANA RV	PHOSPHORUS, TOTAL	MG/L	ANNUAL AVERAGE	11/30/2005	110
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	1/31/2005	576
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	2/28/2005	1008
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	3/31/2005	819
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	4/30/2005	197
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	6/30/2005	251
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	7/31/2005	300
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	9/30/2005	37
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	10/31/2005	25
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	11/30/2005	75
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	12/31/2005	62
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	CYANIDE, TOTAL	UG/L	MAXIMUM	2/28/2005	200
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	CYANIDE, TOTAL	UG/L	MAXIMUM	3/31/2005	200
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	CYANIDE, TOTAL	UG/L	MAXIMUM	4/30/2005	170
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	CYANIDE, TOTAL	UG/L	MAXIMUM	5/31/2005	170
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	CYANIDE, TOTAL	UG/L	MAXIMUM	6/30/2005	170
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	NITRITE PLUS NITRATE TOTAL I DET.	MG/L	ANNUAL AVERAGE	1/31/2005	9
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	NITRITE PLUS NITRATE TOTAL I DET.	MG/L	ANNUAL AVERAGE	2/28/2005	11
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	NITRITE PLUS NITRATE TOTAL I DET.	MG/L	ANNUAL AVERAGE	3/31/2005	10
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	NITRITE PLUS NITRATE TOTAL I DET.	MG/L	ANNUAL AVERAGE	4/30/2005	4
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	ZINC, TOTAL RECOVERABLE	UG/L	MAXIMUM	1/31/2005	28
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	ZINC, TOTAL RECOVERABLE	UG/L	MAXIMUM	2/28/2005	51
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	ZINC, TOTAL RECOVERABLE	UG/L	MAXIMUM	3/31/2005	63
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	ZINC, TOTAL RECOVERABLE	UG/L	MAXIMUM	5/31/2005	7
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	ZINC, TOTAL RECOVERABLE	UG/L	MAXIMUM	6/30/2005	12
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	ZINC, TOTAL RECOVERABLE	UG/L	MAXIMUM	9/30/2005	24
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	ZINC, TOTAL RECOVERABLE	UG/L	MAXIMUM	10/31/2005	3
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	ZINC, TOTAL RECOVERABLE	UG/L	MAXIMUM	11/30/2005	14
F0020559	PORT ORANGE WWTP	VOLUSIA	HALIFAX RV	ZINC, TOTAL RECOVERABLE	UG/L	MAXIMUM	12/31/2005	34
F0020940	HOWARD F CURREN AWTP	HILLSBOROUGH	HILLSBOROUGH BAY	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	7/31/2005	288

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	7/31/2005	40
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	7/31/2005	40
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	2/28/2005	470
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	COLIFORM, FECAL GENERAL	#/100ML	90TH PERCENTILE	2/28/2005	1040
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	CYANIDE, TOTAL	MG/L	MAXIMUM	2/28/2005	400
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	CYANIDE, TOTAL	MG/L	MAXIMUM	3/31/2005	900
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	CYANIDE, TOTAL	MG/L	MAXIMUM	5/31/2005	400
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	CYANIDE, TOTAL	MG/L	MAXIMUM	7/31/2005	400
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	CYANIDE, TOTAL	MG/L	MAXIMUM	8/31/2005	70
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	CYANIDE, TOTAL	MG/L	MAXIMUM	9/30/2005	460
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	CYANIDE, TOTAL	MG/L	MAXIMUM	10/31/2005	1100
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	CYANIDE, TOTAL	MG/L	MAXIMUM	11/30/2005	400
F00021105	COCOA BEACH WTP	BREVARD	BANANA RV	CYANIDE, TOTAL	MG/L	MAXIMUM	12/31/2005	1090
F00021261	FT MYERS-CENTRAL STP	LEE	CALOOSAHATCHEE RIVER	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	8/31/2005	60
F00021261	FT MYERS-CENTRAL STP	LEE	CALOOSAHATCHEE RIVER	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	11/30/2005	40
F00021261	FT MYERS-CENTRAL STP	LEE	CALOOSAHATCHEE RIVER	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	12/31/2005	107
F00021261	FT MYERS-CENTRAL STP	LEE	CALOOSAHATCHEE RIVER	DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	12/31/2005	45
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	12/31/2005	80
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	CHLORODIBROMOMETHANE	UG/L	ANNUAL AVERAGE	12/31/2005	53
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	12/31/2005	3
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	12/31/2005	9
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	MONTHLY AVERAGE	6/30/2005	18
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	MONTHLY AVERAGE	7/31/2005	3
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	NITROGEN, TOTAL	LBS/DAY	MONTHLY AVERAGE	12/31/2005	24
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	12/31/2005	61
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	12/31/2005	115
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	NITROGEN, TOTAL	MG/L	MAXIMUM	12/31/2005	146
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	OXYGEN, DISSOLVED	MG/L	DAILY AVERAGE MINIMUM	6/30/2005	6
F00021270	FT MYERS-SOUTH STP	LEE	CALOOSAHATCHEE RIVER	SOLIDS, TOTAL SUSPENDED	MG/L	WEEKLY AVERAGE	8/31/2005	182
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM SINGLE SAMPLE	11/30/2005	700
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	6/30/2005	2
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	7/31/2005	7
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	8/31/2005	2

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	NOEL STAIRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	7/31/2005	100
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	NOEL STAIRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	7/31/2005	100
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	NOEL STAIRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	7/31/2005	100
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	NOEL STAIRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	7/31/2005	*
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	NOEL STAIRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	1/31/2005	*
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	NOEL STAIRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	7/31/2005	100
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	NOEL STAIRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	7/31/2005	100
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	NOEL STAIRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	7/31/2005	100
F00021369	BRADENTON WTP	MANATEE	MANATEE RV	NOEL STAIRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	9/30/2005	*
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	WEEKLY AVERAGE	4/30/2005	195
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	4/30/2005	319
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	COLIFORM, FECAL GENERAL	#/100ML	90TH PERCENTILE	4/30/2005	40
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	4/30/2005	650
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	2/28/2005	3
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	4/30/2005	3
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	5/31/2005	69
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	8/31/2005	7
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	9/30/2005	17
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	10/31/2005	17
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	11/30/2005	31
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	IRON, TOTAL RECOVERABLE	MG/L	MAXIMUM	1/31/2005	13
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	IRON, TOTAL RECOVERABLE	MG/L	MAXIMUM	6/30/2005	233
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	IRON, TOTAL RECOVERABLE	MG/L	MAXIMUM	12/31/2005	180
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	3/31/2005	5
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	3/31/2005	32
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	NITROGEN, TOTAL	MG/L	MAXIMUM	3/31/2005	63
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	4/30/2005	38
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	4/30/2005	111
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	NITROGEN, TOTAL	MG/L	MAXIMUM	4/30/2005	165
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	6/30/2005	2
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	8/31/2005	2
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	NOEL STAIRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	7/31/2005	*
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	NOEL STAIRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	8/31/2005	50

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	NOEL STAITRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	7/31/2005	3
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	OXYGEN, DISSOLVED	MG/L	MINIMUM	4/30/2005	90
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	OXYGEN, DISSOLVED	MG/L	DAILY AVERAGE MINIMUM	4/30/2005	92
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	PHOSPHORUS, TOTAL	MG/L	WEEKLY AVERAGE	3/31/2005	55
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	3/31/2005	200
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	4/30/2005	17
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	PHOSPHORUS, TOTAL	MG/L	WEEKLY AVERAGE	4/30/2005	303
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	4/30/2005	490
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	PHOSPHORUS, TOTAL	MG/L	WEEKLY AVERAGE	11/30/2005	24
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	11/30/2005	45
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	12/31/2005	48
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	1/31/2005	6
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	2/28/2005	7
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	3/31/2005	22
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	MONTHLY AVERAGE	3/31/2005	124
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	WEEKLY AVERAGE	3/31/2005	614
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	3/31/2005	1350
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	4/30/2005	59
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	MONTHLY AVERAGE	4/30/2005	360
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	WEEKLY AVERAGE	4/30/2005	1847
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	4/30/2005	2763
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	WEEKLY AVERAGE	5/31/2005	11
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	MONTHLY AVERAGE	5/31/2005	39
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	5/31/2005	67
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	5/31/2005	102
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	6/30/2005	67
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	7/31/2005	64
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	8/31/2005	59
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	9/30/2005	54
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	10/31/2005	49
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	11/30/2005	38
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	12/31/2005	2
F00021440	ESCAMBIA CNTY-MAIN STREET WTP	ESCAMBIA	PENSACOLA BAY	ULTRAVIOLET LIGHT DOSAGE	MWS/CM2	MINIMUM	8/31/2005	400

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, KJELDAHL TOTAL	MG/L	MONTHLY AVERAGE	2/28/2005	6
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, KJELDAHL TOTAL	MG/L	MONTHLY AVERAGE	4/30/2005	39
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	3/31/2005	3
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	3/31/2005	56
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	4/30/2005	68
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	4/30/2005	100
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	5/31/2005	11
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	6/30/2005	7
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	6/30/2005	48
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	6/30/2005	56
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	7/31/2005	3
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	7/31/2005	10
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	8/31/2005	5
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	9/30/2005	2
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	10/31/2005	10
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	10/31/2005	11
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	11/30/2005	15
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	12/31/2005	22
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	12/31/2005	27
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	12/31/2005	30
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	1/31/2005	*
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	2/28/2005	*
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	3/31/2005	*
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	3/31/2005	*
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	11/30/2005	*
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	12/31/2005	*
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	2/28/2005	*
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	4/30/2005	*
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	5/31/2005	*
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	12/31/2005	*
F00021466	AUBURNDALE STP	POLK	LAKE LENA RUN AND PEACE RV	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	12/31/2005	*
F00021512	PANAMA CITY BEACH STP	BAY	WEST BAY	COLIFORM, FECAL GENERAL	#/100ML	90TH PERCENTILE	10/31/2005	14
F00021512	PANAMA CITY BEACH STP	BAY	WEST BAY	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	10/31/2005	28

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F00021521	COCOA-WAT POLL CNTL FAC	BREVARD	INDIAN RV	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	10/31/2005	80
F00021521	COCOA-WAT POLL CNTL FAC	BREVARD	INDIAN RV	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	9/30/2005	2
F00021661	VERO BEACH WWTP-INDIAN RIVER	INDIAN RIVER	INDIAN RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	2/28/2005	55
F00021661	VERO BEACH WWTP-INDIAN RIVER	INDIAN RIVER	INDIAN RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	7/31/2005	119
F00021661	VERO BEACH WWTP-INDIAN RIVER	INDIAN RIVER	INDIAN RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	1/31/2005	3
F00021661	VERO BEACH WWTP-INDIAN RIVER	INDIAN RIVER	INDIAN RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	3/31/2005	15
F00021661	VERO BEACH WWTP-INDIAN RIVER	INDIAN RIVER	INDIAN RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	4/30/2005	24
F00021661	VERO BEACH WWTP-INDIAN RIVER	INDIAN RIVER	INDIAN RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	5/31/2005	29
F00021661	VERO BEACH WWTP-INDIAN RIVER	INDIAN RIVER	INDIAN RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	6/30/2005	57
F00021661	VERO BEACH WWTP-INDIAN RIVER	INDIAN RIVER	INDIAN RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	7/31/2005	63
F00021661	VERO BEACH WWTP-INDIAN RIVER	INDIAN RIVER	INDIAN RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	8/31/2005	63
F00021661	VERO BEACH WWTP-INDIAN RIVER	INDIAN RIVER	INDIAN RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	9/30/2005	22
F00021661	VERO BEACH WWTP-INDIAN RIVER	INDIAN RIVER	INDIAN RV	PH	SU	MINIMUM	4/30/2005	2
F00021865	CLEARWATER-EAST WWTF	PINELLAS	TAMPA BAY	COLIFORM, FECAL MF, M-FC BROTH, 44.5C	#/100ML	MAXIMUM	1/31/2005	1216
F00021865	CLEARWATER-EAST WWTF	PINELLAS	TAMPA BAY	COLIFORM, FECAL MF, M-FC BROTH, 44.5C	#/100ML	MAXIMUM	4/30/2005	300
F00021865	CLEARWATER-EAST WWTF	PINELLAS	TAMPA BAY	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	2/28/2005	69
F00021903	MILTON STP	SANTA ROSA	BLACKWATER RV	AMMONIA, UNIONIZED	MG/L	MAXIMUM	9/30/2005	50
F00021903	MILTON STP	SANTA ROSA	BLACKWATER RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	3/31/2005	*
F00021903	MILTON STP	SANTA ROSA	BLACKWATER RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	9/30/2005	*
F00021903	MILTON STP	SANTA ROSA	BLACKWATER RV	NOEL STATRE 7DAY CHR PIMEPHEALS	PERCENT	MINIMUM	9/30/2005	*
F00021938	ST AUGUSTINE STP NO 1	ST JOHNS	MATANZAS RV	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	9/30/2005	28
F00021938	ST AUGUSTINE STP NO 1	ST JOHNS	MATANZAS RV	CYANIDE, TOTAL	UG/L	MAXIMUM	3/31/2005	390
F00021938	ST AUGUSTINE STP NO 1	ST JOHNS	MATANZAS RV	CYANIDE, TOTAL	UG/L	MAXIMUM	8/31/2005	280
F00021938	ST AUGUSTINE STP NO 1	ST JOHNS	MATANZAS RV	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	2/28/2005	190
F00021938	ST AUGUSTINE STP NO 1	ST JOHNS	MATANZAS RV	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	3/31/2005	100
F00021938	ST AUGUSTINE STP NO 1	ST JOHNS	MATANZAS RV	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	4/30/2005	100
F00021938	ST AUGUSTINE STP NO 1	ST JOHNS	MATANZAS RV	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	5/31/2005	376
F00021938	ST AUGUSTINE STP NO 1	ST JOHNS	MATANZAS RV	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	6/30/2005	311
F00021938	ST AUGUSTINE STP NO 1	ST JOHNS	MATANZAS RV	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	7/31/2005	106
F00023493	JEA - MANDARIN WWTF	DUVAL	SAINT JOHNS RIVER	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	8/31/2005	75
F00023604	JEA - MONTEREY WWTF	DUVAL	SAINT JOHNS RIVER	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	7/31/2005	50
F00023604	JEA - MONTEREY WWTF	DUVAL	SAINT JOHNS RIVER	COLIFORM, FECAL GENERAL	#/100ML	90TH PERCENTILE	7/31/2005	200
F00023604	JEA - MONTEREY WWTF	DUVAL	SAINT JOHNS RIVER	COLIFORM, FECAL GENERAL	#/100ML	90TH PERCENTILE	9/30/2005	35

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0023663	JEA - SAN JOSE WWTF	DUVAL	SAINT JOHNS RIVER	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MONTHLY AVERAGE	4/30/2005	4
F0023663	JEA - SAN JOSE WWTF	DUVAL	SAINT JOHNS RIVER	PH	SU	MINIMUM	6/30/2005	3
F0023663	JEA - SAN JOSE WWTF	DUVAL	SAINT JOHNS RIVER	PH	SU	MINIMUM	7/31/2005	2
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	8/31/2005	101
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	9/30/2005	237
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	COLIFORM, FECAL MF, M-FC BROTH, 44.5C	#/100ML	ANNUAL AVERAGE	1/31/2005	8414
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	COLIFORM, FECAL MF, M-FC BROTH, 44.5C	#/100ML	ANNUAL AVERAGE	2/28/2005	22386
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	7/31/2005	19
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	NITROGEN, TOTAL	MG/L	MAXIMUM	7/31/2005	57
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	3/31/2005	*
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	7/31/2005	*
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	8/31/2005	50
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	9/30/2005	*
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	10/31/2005	50
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	10/31/2005	75
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	12/31/2005	50
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	9/30/2005	*
F0024007	SANTA ROSA ISL-PENSCLA BCH STP	ESCAMBIA	SANTA ROSA SOUND	ULTRAVIOLET LIGHT DOSAGE	MWS/CM2	MINIMUM	8/31/2005	23
F0024805	MIAMI-VIRGINIA KEY WTP	DADE	ATLANTIC OCEAN	OVERFLOW USE, OCCURANCES	OCCUR/MONTH	MAXIMUM	2/28/2005	*
F0024805	MIAMI-VIRGINIA KEY WTP	DADE	ATLANTIC OCEAN	OVERFLOW USE, OCCURANCES	OCCUR/MONTH	MAXIMUM	5/31/2005	*
F0024805	MIAMI-VIRGINIA KEY WTP	DADE	ATLANTIC OCEAN	OVERFLOW USE, OCCURANCES	OCCUR/MONTH	MAXIMUM	7/31/2005	*
F0024805	MIAMI-VIRGINIA KEY WTP	DADE	ATLANTIC OCEAN	OVERFLOW USE, OCCURANCES	OCCUR/MONTH	MAXIMUM	8/31/2005	*
F0024805	MIAMI-VIRGINIA KEY WTP	DADE	ATLANTIC OCEAN	OVERFLOW USE, OCCURANCES	OCCUR/MONTH	MAXIMUM	9/30/2005	*
F0024805	MIAMI-VIRGINIA KEY WTP	DADE	ATLANTIC OCEAN	OVERFLOW USE, OCCURANCES	OCCUR/MONTH	MAXIMUM	10/31/2005	*
F0024805	MIAMI-VIRGINIA KEY WTP	DADE	ATLANTIC OCEAN	OVERFLOW USE, OCCURANCES	OCCUR/MONTH	MAXIMUM	11/30/2005	*
F0024805	MIAMI-VIRGINIA KEY WTP	DADE	ATLANTIC OCEAN	SOLIDS, TOTAL SUSPENDED	MG/L	WEEKLY AVERAGE	11/30/2005	10
F0025755	SIESTA KEY UTIL-ISLAND CIRCLE	SARASOTA	GRAND CL TO ROBERTS BAY	% OF FECAL COLIFORM SAMPLES < DETECTABLE	PERCENT	MINIMUM	5/31/2005	33
F0025755	SIESTA KEY UTIL-ISLAND CIRCLE	SARASOTA	GRAND CL TO ROBERTS BAY	% OF FECAL COLIFORM SAMPLES < DETECTABLE	PERCENT	MINIMUM	7/31/2005	99
F0025755	SIESTA KEY UTIL-ISLAND CIRCLE	SARASOTA	GRAND CL TO ROBERTS BAY	CHLORINE, TOTAL RESIDUAL	MG/L	DAILY MINIMUM	1/31/2005	20
F0025755	SIESTA KEY UTIL-ISLAND CIRCLE	SARASOTA	GRAND CL TO ROBERTS BAY	CHLORINE, TOTAL RESIDUAL	MG/L	DAILY MINIMUM	7/31/2005	10
F0025755	SIESTA KEY UTIL-ISLAND CIRCLE	SARASOTA	GRAND CL TO ROBERTS BAY	CHLORINE, TOTAL RESIDUAL	MG/L	DAILY MINIMUM	12/31/2005	10
F0025755	SIESTA KEY UTIL-ISLAND CIRCLE	SARASOTA	GRAND CL TO ROBERTS BAY	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	5/31/2005	700
F0025755	SIESTA KEY UTIL-ISLAND CIRCLE	SARASOTA	GRAND CL TO ROBERTS BAY	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	12/31/2005	68

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0025755	SIESTA KEY UTIL-ISLAND CIRCLE	SARASOTA	GRAND CL TO ROBERTS BAY	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	3/31/2005	1
F0025984	DAYTONA BCH REG/BETH PT WWTP'S	VOLUSIA	HALIFAX RV	CHLORINE, TOTAL RESIDUAL	MG/L	MAXIMUM	1/31/2005	8600
F0025984	DAYTONA BCH REG/BETH PT WWTP'S	VOLUSIA	HALIFAX RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	DAILY MAXIMUM	10/31/2005	4
F0025984	DAYTONA BCH REG/BETH PT WWTP'S	VOLUSIA	HALIFAX RV	NITROGEN, TOTAL	MG/L	MAXIMUM	2/28/2005	13
F0025984	DAYTONA BCH REG/BETH PT WWTP'S	VOLUSIA	HALIFAX RV	NITROGEN, TOTAL	MG/L	MAXIMUM	9/30/2005	12
F0025984	DAYTONA BCH REG/BETH PT WWTP'S	VOLUSIA	HALIFAX RV	OXYGEN, DISSOLVED	MG/L	MINIMUM	6/30/2005	85
F0025984	DAYTONA BCH REG/BETH PT WWTP'S	VOLUSIA	HALIFAX RV	PH	SU	MINIMUM	4/30/2005	2
F0025984	DAYTONA BCH REG/BETH PT WWTP'S	VOLUSIA	HALIFAX RV	PH	SU	MINIMUM	8/31/2005	1
F0025984	DAYTONA BCH REG/BETH PT WWTP'S	VOLUSIA	HALIFAX RV	PH	SU	MINIMUM	10/31/2005	5
F0025984	DAYTONA BCH REG/BETH PT WWTP'S	VOLUSIA	HALIFAX RV	PH	SU	MAXIMUM	10/31/2005	40
F0026000	JEA - BUCKMAN WWTF	DUVAL	SAINT JOHNS RIVER	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	6/30/2005	50
F0026000	JEA - BUCKMAN WWTF	DUVAL	SAINT JOHNS RIVER	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	7/31/2005	175
F0026000	JEA - BUCKMAN WWTF	DUVAL	SAINT JOHNS RIVER	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	8/31/2005	50
F0026255	HOLLYWOOD WTP	BROWARD	ATLANTIC OCEAN	CHLORINE, TOTAL RESIDUAL	MG/L	MAXIMUM	8/31/2005	26
F0026255	HOLLYWOOD WTP	BROWARD	ATLANTIC OCEAN	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	3/31/2005	32
F0026255	HOLLYWOOD WTP	BROWARD	ATLANTIC OCEAN	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	4/30/2005	28
F0026255	HOLLYWOOD WTP	BROWARD	ATLANTIC OCEAN	SOLIDS, TOTAL SUSPENDED	MG/L	MONTHLY AVERAGE	7/31/2005	11
F0026255	HOLLYWOOD WTP	BROWARD	ATLANTIC OCEAN	SOLIDS, TOTAL SUSPENDED	MG/L	WEEKLY AVERAGE	7/31/2005	40
F0026255	HOLLYWOOD WTP	BROWARD	ATLANTIC OCEAN	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	7/31/2005	92
F0026255	HOLLYWOOD WTP	BROWARD	ATLANTIC OCEAN	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	8/31/2005	2
F0026255	HOLLYWOOD WTP	BROWARD	ATLANTIC OCEAN	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	9/30/2005	138
F0026271	NAPLES-MUNICIPAL PLANT	COLLIER	GORDON RV	COLIFORM, FECAL MF, M-FC BROTH, 44.5C	#/100ML	DAILY MAXIMUM	1/31/2005	28
F0026271	NAPLES-MUNICIPAL PLANT	COLLIER	GORDON RV	SOLIDS, TOTAL SUSPENDED	MG/L	DAILY MAXIMUM	6/30/2005	140
F0026387	PERRY STP	COLLIER	GORDON RV	SURFACTANTS (MBAS)	MG/L	MAXIMUM	4/30/2005	2960
F0026387	PERRY STP	TAYLOR	SPRING CREEK	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	5/31/2005	84
F0026387	PERRY STP	TAYLOR	SPRING CREEK	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	6/30/2005	86
F0026387	PERRY STP	TAYLOR	SPRING CREEK	MERCURY, TOTAL RECOVERABLE	UG/L	MAXIMUM	12/31/2005	1067
F0026387	PERRY STP	TAYLOR	SPRING CREEK	NOEL STATRE 7DAY CHR CERIODAPHMIA	PERCENT	MINIMUM	3/31/2005	50
F0026387	PERRY STP	TAYLOR	SPRING CREEK	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	12/31/2005	94
F0026387	PERRY STP	TAYLOR	SPRING CREEK	SILVER, TOTAL RECOVERABLE	UG/L	MAXIMUM	3/31/2005	114
F0026387	PERRY STP	TAYLOR	SPRING CREEK	SILVER, TOTAL RECOVERABLE	UG/L	MAXIMUM	6/30/2005	86
F0026387	PERRY STP	TAYLOR	SPRING CREEK	SILVER, TOTAL RECOVERABLE	UG/L	MAXIMUM	12/31/2005	371
F0026468	JEA - SOUTHWEST WWTF	DUVAL	SAINT JOHNS RIVER	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	8/31/2005	75

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0026557	PLANT CITY STP	HILLSBOROUGH	WEST SIDE CANAL TO PEMBERTON CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	7/31/2005	25
F0026557	PLANT CITY STP	HILLSBOROUGH	WEST SIDE CANAL TO PEMBERTON CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	8/31/2005	18
F0026557	PLANT CITY STP	HILLSBOROUGH	WEST SIDE CANAL TO PEMBERTON CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	9/30/2005	6
F0026557	PLANT CITY STP	HILLSBOROUGH	WEST SIDE CANAL TO PEMBERTON CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	10/31/2005	2
F0026557	PLANT CITY STP	HILLSBOROUGH	WEST SIDE CANAL TO PEMBERTON CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	11/30/2005	3
F0026557	PLANT CITY STP	HILLSBOROUGH	WEST SIDE CANAL TO PEMBERTON CREEK	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	12/31/2005	3
F0026557	PLANT CITY STP	HILLSBOROUGH	WEST SIDE CANAL TO PEMBERTON CREEK	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	6/30/2005	2
F0026557	PLANT CITY STP	HILLSBOROUGH	WEST SIDE CANAL TO PEMBERTON CREEK	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	9/30/2005	*
F0026603	LARGO STP	PINELLAS	TAMPA BAY VIA CROSS BAYOU	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	3/31/2005	40
F0026603	LARGO STP	PINELLAS	TAMPA BAY VIA CROSS BAYOU	CHLORINE, TOTAL RESIDUAL	MG/L	DAILY MAXIMUM	3/31/2005	4900
F0026603	LARGO STP	PINELLAS	TAMPA BAY VIA CROSS BAYOU	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	6/30/2005	26
F0026603	LARGO STP	PINELLAS	TAMPA BAY VIA CROSS BAYOU	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	10/31/2005	40
F0026603	LARGO STP	PINELLAS	TAMPA BAY VIA CROSS BAYOU	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	12/31/2005	20
F0026603	LARGO STP	PINELLAS	TAMPA BAY VIA CROSS BAYOU	NITROGEN, TOTAL	MG/L	MAXIMUM	6/30/2005	10
F0026603	LARGO STP	PINELLAS	TAMPA BAY VIA CROSS BAYOU	PH	SU	MINIMUM	11/30/2005	2
F0026611	FLAGLER BEACH WTP	FLAGLER	INTRACOASTAL WATERWAY	LC50 STATRE 96HR ACU MENDIA	PERCENT	MINIMUM	8/31/2005	*
F0026611	FLAGLER BEACH WTP	FLAGLER	INTRACOASTAL WATERWAY	LC50 STATRE 96HR ACU MYSID. BAHIA	PERCENT	MINIMUM	8/31/2005	*
F0026751	JEA - ROYAL LAKES WWTF	DUVAL	POITTSBURG CREEK	AMMONIA, UNIONIZED	MG/L	MAXIMUM	7/31/2005	23
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	5/31/2005	17
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NITROGEN, TOTAL	MG/L	MAXIMUM	5/31/2005	101
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NITROGEN, TOTAL	MG/L	MAXIMUM	6/30/2005	16
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	7/31/2005	57
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NITROGEN, TOTAL	MG/L	MAXIMUM	7/31/2005	82
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	10/31/2005	4
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NITROGEN, TOTAL	MG/L	MAXIMUM	10/31/2005	29
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	11/30/2005	17
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NITROGEN, TOTAL	MG/L	MAXIMUM	11/30/2005	160
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	11/30/2005	193
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	12/31/2005	10
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	12/31/2005	30
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	1/31/2005	*
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	12/31/2005	10
F0026867	BLOUNTSTOWN-STP	CALHOUN	SUTTON CR	ULTRAVIOLET LIGHT INTENSITY	IUV/CM2	MINIMUM	8/31/2005	4

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F002751	GAINESVILLE-MAIN ST WTP 1&2	ALACHUA	SWEETWATER BR	NOEL STAITRE 7DAY CHR CERIODAPHRINA	PERCENT	MINIMUM	7/31/2005	*
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	AMMONIA, UNIONIZED	MG/L	MAXIMUM	1/31/2005	75
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	AMMONIA, UNIONIZED	MG/L	MAXIMUM	2/28/2005	125
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	AMMONIA, UNIONIZED	MG/L	MAXIMUM	3/31/2005	157
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	AMMONIA, UNIONIZED	MG/L	MAXIMUM	9/30/2005	223
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	AMMONIA, UNIONIZED	MG/L	MAXIMUM	10/31/2005	50
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	AMMONIA, UNIONIZED	MG/L	MAXIMUM	11/30/2005	175
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MONTHLY AVERAGE	1/31/2005	33
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	ANNUAL AVERAGE	9/30/2005	1
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MONTHLY AVERAGE	9/30/2005	4
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	9/30/2005	11
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	6/30/2005	1
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	QUARTERLY ROLLING AVERAGE	6/30/2005	5
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	7/31/2005	6
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	QUARTERLY ROLLING AVERAGE	7/31/2005	23
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	QUARTERLY ROLLING AVERAGE	8/31/2005	37
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MAXIMUM	1/31/2005	120
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MONTHLY AVERAGE	1/31/2005	171
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	ANNUAL AVERAGE	2/28/2005	8
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MAXIMUM	2/28/2005	31
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MONTHLY AVERAGE	2/28/2005	83
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	ANNUAL AVERAGE	3/31/2005	11
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MAXIMUM	3/31/2005	25
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MONTHLY AVERAGE	3/31/2005	32
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	ANNUAL AVERAGE	4/30/2005	10
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	ANNUAL AVERAGE	5/31/2005	8
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	ANNUAL AVERAGE	6/30/2005	10
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	ANNUAL AVERAGE	7/31/2005	13
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	ANNUAL AVERAGE	8/31/2005	13
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	ANNUAL AVERAGE	9/30/2005	18
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MAXIMUM	10/31/2005	20
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MONTHLY AVERAGE	10/31/2005	20
F002751	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	ANNUAL AVERAGE	10/31/2005	28

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0027511	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MAXIMUM	11/30/2005	21
F0027511	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	ANNUAL AVERAGE	11/30/2005	38
F0027511	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MONTHLY AVERAGE	11/30/2005	65
F0027511	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MAXIMUM	12/31/2005	8
F0027511	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	ANNUAL AVERAGE	12/31/2005	46
F0027511	ARCADIA - WILLIAM TYSON WWTP	DE SOTO	PEACE RIVER	NITROGEN, KJELDAHL TOTAL	MG/L	MONTHLY AVERAGE	12/31/2005	55
F0027570	CHIPLEY WATER & SEWER SYSTEM	WASHINGTON	ALLIGATOR CR	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	MONTHLY AVERAGE	4/30/2005	37
F0027570	CHIPLEY WATER & SEWER SYSTEM	WASHINGTON	ALLIGATOR CR	IRON, TOTAL RECOVERABLE	MG/L	MAXIMUM	6/30/2005	26
F0027570	CHIPLEY WATER & SEWER SYSTEM	WASHINGTON	ALLIGATOR CR	NITROGEN, AMMONIA, TOTAL UNIONIZED	MG/L	MAXIMUM	6/30/2005	300
F0027570	CHIPLEY WATER & SEWER SYSTEM	WASHINGTON	ALLIGATOR CR	NITROGEN, TOTAL	MG/L	MAXIMUM	11/30/2005	2
F0027570	CHIPLEY WATER & SEWER SYSTEM	WASHINGTON	ALLIGATOR CR	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	11/30/2005	4
F0027600	IMC-AGRICO CO - FT GREEN MINE	POLK	PAYNE CR	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	3/31/2005	18
F0027600	IMC-AGRICO CO - FT GREEN MINE	POLK	PAYNE CR	PH	SU	DAILY MAXIMUM	2/28/2005	2
F0027651	OLDSMAR	PINELLAS	DRAINAGE SYSTEM TO MOBBLY BAYOU	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	9/30/2005	27
F0027677	HOLLY HILL ADVANCED WWTF	VOLUSIA	HALIFAX RV	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	5/31/2005	9
F0027677	HOLLY HILL ADVANCED WWTF	VOLUSIA	HALIFAX RV	NITROGEN, TOTAL	LBS/DAY	MONTHLY AVERAGE	6/30/2005	3
F0027677	HOLLY HILL ADVANCED WWTF	VOLUSIA	HALIFAX RV	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	8/31/2005	1
F0027677	HOLLY HILL ADVANCED WWTF	VOLUSIA	HALIFAX RV	NITROGEN, TOTAL	LBS/DAY	MONTHLY AVERAGE	9/30/2005	3
F0027677	HOLLY HILL ADVANCED WWTF	VOLUSIA	HALIFAX RV	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	9/30/2005	37
F0027677	HOLLY HILL ADVANCED WWTF	VOLUSIA	HALIFAX RV	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	10/31/2005	17
F0027677	HOLLY HILL ADVANCED WWTF	VOLUSIA	HALIFAX RV	NITROGEN, TOTAL	LBS/DAY	MONTHLY AVERAGE	10/31/2005	32
F0027677	HOLLY HILL ADVANCED WWTF	VOLUSIA	HALIFAX RV	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	11/30/2005	11
F0027821	RIVER OAKS AWWTP	HILLSBOROUGH	CHANNEL A	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	1/31/2005	137
F0027821	RIVER OAKS AWWTP	HILLSBOROUGH	CHANNEL A	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	1/31/2005	30
F0027821	RIVER OAKS AWWTP	HILLSBOROUGH	CHANNEL A	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	3/31/2005	50
F0027821	RIVER OAKS AWWTP	HILLSBOROUGH	CHANNEL A	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	5/31/2005	70
F0027821	RIVER OAKS AWWTP	HILLSBOROUGH	CHANNEL A	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	11/30/2005	80
F0027821	RIVER OAKS AWWTP	HILLSBOROUGH	CHANNEL A	NITROGEN, TOTAL	MG/L	MAXIMUM	1/31/2005	151
F0027821	RIVER OAKS AWWTP	HILLSBOROUGH	CHANNEL A	NITROGEN, TOTAL	MG/L	MAXIMUM	3/31/2005	38
F0027821	RIVER OAKS AWWTP	HILLSBOROUGH	CHANNEL A	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	1/31/2005	60
F0027821	RIVER OAKS AWWTP	HILLSBOROUGH	CHANNEL A	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	1/31/2005	160
F0027839	MONTICELLO-5TP	JEFFERSON	AUCILLA RV	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	8/31/2005	98
F0027839	MONTICELLO-5TP	JEFFERSON	AUCILLA RV	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	10/31/2005	98

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	ANNUAL AVERAGE	1/31/2005	8
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	MONTHLY GEOMETRIC MEAN	1/31/2005	840
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	ANNUAL AVERAGE	2/28/2005	6
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	MONTHLY GEOMETRIC MEAN	3/31/2005	500
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	3/31/2005	650
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	ANNUAL AVERAGE	4/30/2005	49
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	ANNUAL AVERAGE	5/31/2005	48
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	ANNUAL AVERAGE	6/30/2005	47
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	ANNUAL AVERAGE	7/31/2005	45
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	ANNUAL AVERAGE	9/30/2005	45
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	ANNUAL AVERAGE	10/31/2005	31
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	ANNUAL AVERAGE	11/30/2005	31
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	COLIFORM, FECAL GENERAL	#/100ML	ANNUAL AVERAGE	12/31/2005	29
F0027839	MONTICELLO-STP	JEFFERSON	AUCILLA RV	SOLIDS, TOTAL SUSPENDED	MG/L	MONTHLY AVERAGE	6/30/2005	42
F0027880	JASPER-WWTP	HAMILTON	BAIRDEN SWAMP	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	3/31/2005	1004
F0027880	JASPER-WWTP	HAMILTON	BAIRDEN SWAMP	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	5/31/2005	44
F0027880	JASPER-WWTP	HAMILTON	BAIRDEN SWAMP	NITROGEN, AMMONIA TOTAL	MG/L	MAXIMUM	5/31/2005	38
F0027880	JASPER-WWTP	HAMILTON	BAIRDEN SWAMP	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	2/28/2005	56
F0027880	JASPER-WWTP	HAMILTON	BAIRDEN SWAMP	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	2/28/2005	191
F0027880	JASPER-WWTP	HAMILTON	BAIRDEN SWAMP	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	7/31/2005	39
F0027880	JASPER-WWTP	HAMILTON	BAIRDEN SWAMP	PHOSPHORUS, TOTAL	MG/L	ANNUAL AVERAGE	10/31/2005	5
F0027880	JASPER-WWTP	HAMILTON	BAIRDEN SWAMP	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	11/30/2005	5
F0027880	JASPER-WWTP	HAMILTON	BAIRDEN SWAMP	PHOSPHORUS, TOTAL	MG/L	ANNUAL AVERAGE	11/30/2005	10
F0027880	JASPER-WWTP	HAMILTON	BAIRDEN SWAMP	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	11/30/2005	13
F0027880	JASPER-WWTP	HAMILTON	BAIRDEN SWAMP	PHOSPHORUS, TOTAL	MG/L	ANNUAL AVERAGE	12/31/2005	7
F0028061	HILLSBOROUGH CO-SOUTHWEST WTP	HILLSBOROUGH	PORT REDWING CANAL	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	11/30/2005	5
F0028126	STARKE-MUNICIPAL STP	BRADFORD	ALLIGATOR CR	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MONTHLY AVERAGE	10/31/2005	40
F0028126	STARKE-MUNICIPAL STP	BRADFORD	ALLIGATOR CR	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	10/31/2005	54
F0028126	STARKE-MUNICIPAL STP	BRADFORD	ALLIGATOR CR	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MONTHLY AVERAGE	11/30/2005	140
F0028126	STARKE-MUNICIPAL STP	BRADFORD	ALLIGATOR CR	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	11/30/2005	317
F0028126	STARKE-MUNICIPAL STP	BRADFORD	ALLIGATOR CR	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MONTHLY AVERAGE	12/31/2005	17
F0028126	STARKE-MUNICIPAL STP	BRADFORD	ALLIGATOR CR	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	12/31/2005	58
F0029033	CITY OF QUINCY WWTP	GADSDEN	QUINCY CR	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	4/30/2005	94

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0029033	CITY OF QUINCY WWTP	GADSDEN	QUINCY CR	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	5/31/2005	50
F0029033	CITY OF QUINCY WWTP	GADSDEN	QUINCY CR	CHLORINE, TOTAL RESIDUAL	MG/L	MAXIMUM	7/31/2005	8800
F0029033	CITY OF QUINCY WWTP	GADSDEN	QUINCY CR	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	11/30/2005	40
F0029033	CITY OF QUINCY WWTP	GADSDEN	QUINCY CR	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	6/30/2005	3
F0029033	CITY OF QUINCY WWTP	GADSDEN	QUINCY CR	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	9/30/2005	6
F0030007	CITY OF CAPE CORAL	LEE	CALOOSAHATCHIE RIVER	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	MONTHLY AVERAGE	3/31/2005	2
F0030007	CITY OF CAPE CORAL	LEE	CALOOSAHATCHIE RIVER	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	MONTHLY AVERAGE	9/30/2005	22
F0030007	CITY OF CAPE CORAL	LEE	CALOOSAHATCHIE RIVER	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	5/31/2005	334
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	3/31/2005	1
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	5/31/2005	5
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	MAXIMUM	6/30/2005	77
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	7/31/2005	14
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	MAXIMUM	7/31/2005	60
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	8/31/2005	14
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	MAXIMUM	9/30/2005	1
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	9/30/2005	14
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	10/31/2005	14
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	MAXIMUM	10/31/2005	26
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	11/30/2005	17
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	ANNUAL AVERAGE	12/31/2005	18
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	NITROGEN, TOTAL	LBS/DAY	MONTHLY MAXIMUM	6/30/2005	63
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	NITROGEN, TOTAL	LBS/DAY	MONTHLY MAXIMUM	10/31/2005	16
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	3/31/2005	248
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	6/30/2005	22
F0030325	FL CITIES WATER-WATERWAY EST	LEE	CALOOSAHATCHIE RV	ULTRAVIOLET LIGHT INTENSITY	UW/CM2	MINIMUM	6/30/2005	100
F0030988	FL PWR & LT-MARTIN CNTY STEAM	MARTIN	ST LUCIE CL	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	3/31/2005	430
F0030988	FL PWR & LT-MARTIN CNTY STEAM	MARTIN	ST LUCIE CL	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	3/31/2005	74
F0030988	FL PWR & LT-MARTIN CNTY STEAM	MARTIN	ST LUCIE CL	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	3/31/2005	80
F0030988	FL PWR & LT-MARTIN CNTY STEAM	MARTIN	ST LUCIE CL	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	3/31/2005	86
F0030988	FL PWR & LT-MARTIN CNTY STEAM	MARTIN	ST LUCIE CL	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	6/30/2005	92
F0030988	FL PWR & LT-MARTIN CNTY STEAM	MARTIN	ST LUCIE CL	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	6/30/2005	92
F0030988	FL PWR & LT-MARTIN CNTY STEAM	MARTIN	ST LUCIE CL	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	6/30/2005	96
F0030988	FL PWR & LT-MARTIN CNTY STEAM	MARTIN	ST LUCIE CL	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	9/30/2005	80

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0030988	FL PWR & LI-MARTIN CNTY STEAM	MARTIN	ST LUCIE CL	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	12/31/2005	58
F0030988	FL PWR & LI-MARTIN CNTY STEAM	MARTIN	ST LUCIE CL	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	12/31/2005	62
F0030988	FL PWR & LI-MARTIN CNTY STEAM	MARTIN	ST LUCIE CL	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	12/31/2005	84
F0031771	BROWARD CO-NO REG PLT-WWTP	BROWARD	ATLANTIC OCEAN	CHLORINE, TOTAL RESIDUAL	MG/L	1 HOUR AVERAGE	6/30/2005	27
F0031771	BROWARD CO-NO REG PLT-WWTP	BROWARD	ATLANTIC OCEAN	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	6/30/2005	75
F0031771	BROWARD CO-NO REG PLT-WWTP	BROWARD	ATLANTIC OCEAN	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	7/31/2005	25
F0031771	BROWARD CO-NO REG PLT-WWTP	BROWARD	ATLANTIC OCEAN	CHLORINE, TOTAL RESIDUAL	MG/L	1 HOUR AVERAGE	8/31/2005	73
F0031771	BROWARD CO-NO REG PLT-WWTP	BROWARD	ATLANTIC OCEAN	CHLORINE, TOTAL RESIDUAL	MG/L	1 HOUR AVERAGE	10/31/2005	87
F0031771	BROWARD CO-NO REG PLT-WWTP	BROWARD	ATLANTIC OCEAN	CHLORINE, TOTAL RESIDUAL	MG/L	1 HOUR AVERAGE	11/30/2005	20
F0031771	BROWARD CO-NO REG PLT-WWTP	BROWARD	ATLANTIC OCEAN	CHLORINE, TOTAL RESIDUAL	MG/L	1 HOUR AVERAGE	12/31/2005	133
F0031801	ESCAMBIA CTY - BAYOU MARCUS	ESCAMBIA	BAYOU MARCUS CREEK	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	5/31/2005	16
F0031801	ESCAMBIA CTY - BAYOU MARCUS	ESCAMBIA	BAYOU MARCUS CREEK	SOLIDS, TOTAL SUSPENDED	MG/L	WEEKLY AVERAGE	12/31/2005	81
F0031801	ESCAMBIA CTY - BAYOU MARCUS	ESCAMBIA	BAYOU MARCUS CREEK	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	12/31/2005	416
F0032174	FL PWR & LI-MANATEE STEAM	MANATEE	LITTLE MANATEE RV	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	3/31/2005	750
F0032174	FL PWR & LI-MANATEE STEAM	MANATEE	LITTLE MANATEE RV	IRON, TOTAL RECOVERABLE	MG/L	DAILY MAXIMUM	4/30/2005	230
F0032522	WINGATE CREEK MINE	MANATEE	WINGATE CR	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	8/31/2005	13
F0032808	SOUTH GATE AWWTP	SARASOTA	PHILLIPPI CR	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	2/28/2005	*
F0032808	SOUTH GATE AWWTP	SARASOTA	PHILLIPPI CR	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	4/30/2005	*
F0032808	SOUTH GATE AWWTP	SARASOTA	PHILLIPPI CR	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	5/31/2005	*
F0032808	SOUTH GATE AWWTP	SARASOTA	PHILLIPPI CR	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	1/31/2005	20
F0032808	SOUTH GATE AWWTP	SARASOTA	PHILLIPPI CR	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	3/31/2005	26
F0032808	SOUTH GATE AWWTP	SARASOTA	PHILLIPPI CR	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	6/30/2005	12
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	7/31/2005	4
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	11/30/2005	2
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	NITROGEN, AMMONIA TOTAL	MG/L	MONTHLY AVERAGE	1/31/2005	22
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	NITROGEN, AMMONIA TOTAL	MG/L	MONTHLY AVERAGE	2/28/2005	52
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	NITROGEN, AMMONIA, TOTAL UNIONIZED	MG/L	MAXIMUM	1/31/2005	90
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	NITROGEN, AMMONIA, TOTAL UNIONIZED	MG/L	MAXIMUM	2/28/2005	55
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	NITROGEN, TOTAL	MG/L	MAXIMUM	1/31/2005	47
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	4/30/2005	*
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	10/31/2005	*
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	NOEL STATRE 7DAY CHR PIMEPHALES	PERCENT	MINIMUM	4/30/2005	*
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	PH	SU	MINIMUM	9/30/2005	2

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0032816	FL CITIES WATER CO - GULF GATE	SARASOTA	MATHENY CR	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	9/30/2005	53
F0033294	HOOKERS PRAIRIE MINE	POLK	LAKE BR HEADWATERS	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	6/30/2005	3
F0033294	HOOKERS PRAIRIE MINE	POLK	LAKE BR HEADWATERS	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	1/31/2005	30
F0033294	HOOKERS PRAIRIE MINE	POLK	LAKE BR HEADWATERS	SOLIDS, FIXED SUSPENDED	MG/L	MONTHLY AVERAGE	6/30/2005	15
F0034657	CORONET INDUSTRIES INC	HILLSBOROUGH	CL-ENGLISH CR	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	8/31/2005	18
F0034657	CORONET INDUSTRIES INC	HILLSBOROUGH	CL-ENGLISH CR	PH	SU	MINIMUM	6/30/2005	3
F0034657	CORONET INDUSTRIES INC	HILLSBOROUGH	CL-ENGLISH CR	PH	SU	MAXIMUM	6/30/2005	9
F0034657	CORONET INDUSTRIES INC	HILLSBOROUGH	CL-ENGLISH CR	PH	SU	DAILY MAXIMUM	7/31/2005	1
F0034657	CORONET INDUSTRIES INC	HILLSBOROUGH	CL-ENGLISH CR	PH	SU	DAILY MINIMUM	11/30/2005	1
F0034657	CORONET INDUSTRIES INC	HILLSBOROUGH	CL-ENGLISH CR	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	1/31/2005	14
F0034657	CORONET INDUSTRIES INC	HILLSBOROUGH	CL-ENGLISH CR	SPECIFIC CONDUCTANCE	UMHO/CM	DAILY MAXIMUM	9/30/2005	2
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	FECAL COLIFORM, MPN,EC MED, 44.5C	#/100ML	MAXIMUM	6/30/2005	48
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	7/31/2005	189
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	NITROGEN, TOTAL	MG/L	MAXIMUM	7/31/2005	233
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	8/31/2005	30
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	NITROGEN, TOTAL	MG/L	MAXIMUM	8/31/2005	55
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	12/31/2005	78
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	NITROGEN, TOTAL	MG/L	MAXIMUM	12/31/2005	117
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	4/30/2005	*
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	9/30/2005	*
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	9/30/2005	*
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	PHOSPHOROUS, IN TOTAL ORTHOPHOSPHATE	MG/L	MAXIMUM	6/30/2005	5
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	PHOSPHOROUS, IN TOTAL ORTHOPHOSPHATE	MG/L	MONTHLY AVERAGE	11/30/2005	18
F0034789	MID-COUNTY SERVICES, INC(DYNA-	PINELLAS	CURLEW CR, ST JOSEPH SOUND	PHOSPHOROUS, IN TOTAL ORTHOPHOSPHATE	MG/L	MAXIMUM	11/30/2005	130
F0035335	VENICE REVERSE OSMOSIS WTP	SARASOTA	HATCHETT CR	COPPER, TOTAL RECOVERABLE	UG/L	DAILY MAXIMUM	5/31/2005	459
F0035335	VENICE REVERSE OSMOSIS WTP	SARASOTA	HATCHETT CR	COPPER, TOTAL RECOVERABLE	UG/L	DAILY MAXIMUM	6/30/2005	472
F0035335	VENICE REVERSE OSMOSIS WTP	SARASOTA	HATCHETT CR	HYDROGEN SULFIDE	MG/L	DAILY MAXIMUM	1/31/2005	3550
F0035335	VENICE REVERSE OSMOSIS WTP	SARASOTA	HATCHETT CR	HYDROGEN SULFIDE	MG/L	DAILY MAXIMUM	4/30/2005	675
F0035335	VENICE REVERSE OSMOSIS WTP	SARASOTA	HATCHETT CR	HYDROGEN SULFIDE	MG/L	DAILY MAXIMUM	7/31/2005	947
F0035980	SO. CENTRAL -WW DISP. BD.	PALM BEACH	ATLANTIC OCEAN	LC50 STATRE 96HR ACU MENIDIA	PERCENT	MINIMUM	2/28/2005	*
F0035980	SO. CENTRAL -WW DISP. BD.	PALM BEACH	ATLANTIC OCEAN	LC50 STATRE 96HR ACU MENIDIA	PERCENT	MINIMUM	2/28/2005	*
F0035980	SO. CENTRAL -WW DISP. BD.	PALM BEACH	ATLANTIC OCEAN	LC50 STATRE 96HR ACU MENIDIA	PERCENT	MINIMUM	9/30/2005	*
F0035980	SO. CENTRAL -WW DISP. BD.	PALM BEACH	ATLANTIC OCEAN	LC50 STATRE 96HR ACU MENIDIA	PERCENT	MINIMUM	10/31/2005	*

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0035980	SO. CENTRAL -WW DISP. BD.	PALM BEACH	ATLANTIC OCEAN	LC50 STATRE 96HR ACU MENIDIA	PERCENT	MINIMUM	10/31/2005	*
F0035980	SO. CENTRAL -WW DISP. BD.	PALM BEACH	ATLANTIC OCEAN	LC50 STATRE 96HR ACU MYSID. BAHIA	PERCENT	MINIMUM	2/28/2005	*
F0035980	SO. CENTRAL -WW DISP. BD.	PALM BEACH	ATLANTIC OCEAN	LC50 STATRE 96HR ACU MYSID. BAHIA	PERCENT	MINIMUM	2/28/2005	*
F0035980	SO. CENTRAL -WW DISP. BD.	PALM BEACH	ATLANTIC OCEAN	LC50 STATRE 96HR ACU MYSID. BAHIA	PERCENT	MINIMUM	9/30/2005	*
F0035980	SO. CENTRAL -WW DISP. BD.	PALM BEACH	ATLANTIC OCEAN	LC50 STATRE 96HR ACU MYSID. BAHIA	PERCENT	MINIMUM	10/31/2005	*
F0035980	SO. CENTRAL -WW DISP. BD.	PALM BEACH	ATLANTIC OCEAN	LC50 STATRE 96HR ACU MYSID. BAHIA	PERCENT	MINIMUM	10/31/2005	*
F0036226	PCS PHOSPATE WHITE SPRINGS-	HAMILTON	DITCH	NOEL STATRE 7DAY CHR PIPEPHALES	PERCENT	MINIMUM	1/31/2005	*
F0036226	PCS PHOSPATE WHITE SPRINGS-	HAMILTON	DITCH	NOEL STATRE 7DAY CHR PIPEPHALES	PERCENT	MINIMUM	12/31/2005	*
F0036251	WEKIWA HUNT CLUB, STP	SEMINOLE	SWEETWATER CR-WEKIWA RV	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MONTHLY AVERAGE	7/31/2005	4
F0036251	WEKIWA HUNT CLUB, STP	SEMINOLE	SWEETWATER CR-WEKIWA RV	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	6/30/2005	68
F0036251	WEKIWA HUNT CLUB, STP	SEMINOLE	SWEETWATER CR-WEKIWA RV	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	6/30/2005	110
F0036251	WEKIWA HUNT CLUB, STP	SEMINOLE	SWEETWATER CR-WEKIWA RV	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	9/30/2005	67
F0036251	WEKIWA HUNT CLUB, STP	SEMINOLE	SWEETWATER CR-WEKIWA RV	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	9/30/2005	120
F0036251	WEKIWA HUNT CLUB, STP	SEMINOLE	SWEETWATER CR-WEKIWA RV	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	10/31/2005	8
F0036498	SEMINOLE ELEC-SEMINOLE STEAM	PUTNAM	ST JOHNS RV	CYANIDE, TOTAL RECOVERABLE	UG/L	INSTANTANEOUS MAXIMUM	12/31/2005	62
F0036498	SEMINOLE ELEC-SEMINOLE STEAM	PUTNAM	ST JOHNS RV	LC50 STATRE 96HR ACU MYSID. BAHIA	PERCENT	DAILY MINIMUM	6/30/2005	*
F0036498	SEMINOLE ELEC-SEMINOLE STEAM	PUTNAM	ST JOHNS RV	LC50 STATRE 96HR ACU MYSID. BAHIA	PERCENT	DAILY MINIMUM	9/30/2005	*
F0036498	SEMINOLE ELEC-SEMINOLE STEAM	PUTNAM	ST JOHNS RV	LC50 STATRE 96HR ACU MYSID. BAHIA	PERCENT	DAILY MINIMUM	12/31/2005	*
F0036820	HILLSBOROUGH CTY - DALE MABRY	HILLSBOROUGH	BRUSHY CR	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	8/31/2005	22
F0036820	HILLSBOROUGH CTY - DALE MABRY	HILLSBOROUGH	BRUSHY CR	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	6/30/2005	100
F0036820	HILLSBOROUGH CTY - DALE MABRY	HILLSBOROUGH	BRUSHY CR	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	5/31/2005	22
F0036820	HILLSBOROUGH CTY - DALE MABRY	HILLSBOROUGH	BRUSHY CR	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	5/31/2005	38
F0036820	HILLSBOROUGH CTY - DALE MABRY	HILLSBOROUGH	BRUSHY CR	NITROGEN, TOTAL	MG/L	MAXIMUM	5/31/2005	41
F0036820	HILLSBOROUGH CTY - DALE MABRY	HILLSBOROUGH	BRUSHY CR	NITROGEN, TOTAL	MG/L	MAXIMUM	6/30/2005	1
F0036820	HILLSBOROUGH CTY - DALE MABRY	HILLSBOROUGH	BRUSHY CR	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	6/30/2005	27
F0036820	HILLSBOROUGH CTY - DALE MABRY	HILLSBOROUGH	BRUSHY CR	NITROGEN, TOTAL	MG/L	MAXIMUM	10/31/2005	3
F0037869	JEA - SAINT JOHNS RIVER POWER	DUVAL	ST JOHNS RV	OIL & GREASE (FREON EXTR.-IR METH)TOT,RC	LBS/DAY	DAILY MAXIMUM	4/30/2005	422
F0037966	ORLANDO-IRON BRIDGE FAC	SEMINOLE	LITTLE ECONLOCKHATCHEE RV	CHLORINE, TOTAL RESIDUAL	MG/L	MAXIMUM	8/31/2005	2500
F0037966	ORLANDO-IRON BRIDGE FAC	SEMINOLE	LITTLE ECONLOCKHATCHEE RV	NITROGEN, KJELDAHL TOTAL	MG/L	MAXIMUM	1/31/2005	7
F0037966	ORLANDO-IRON BRIDGE FAC	SEMINOLE	LITTLE ECONLOCKHATCHEE RV	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	9/30/2005	36
F0037966	ORLANDO-IRON BRIDGE FAC	SEMINOLE	LITTLE ECONLOCKHATCHEE RV	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	11/30/2005	30
F0037966	ORLANDO-IRON BRIDGE FAC	SEMINOLE	LITTLE ECONLOCKHATCHEE RV	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	2/28/2005	73
F0037966	ORLANDO-IRON BRIDGE FAC	SEMINOLE	LITTLE ECONLOCKHATCHEE RV	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	9/30/2005	23

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0037966	ORLANDO-IRON BRIDGE FAC	SEMINOLE	LITTLE ECONLOCKHATCHEE RV	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	11/30/2005	63
F0038652	FARMLAND HYDRO L.P.	HILLSBOROUGH	PORT SUTTON CHANNEL	PH	SU	MAXIMUM	4/30/2005	5
F0038652	FARMLAND HYDRO L.P.	HILLSBOROUGH	PORT SUTTON CHANNEL	PH	SU	MAXIMUM	5/31/2005	5
F0038652	FARMLAND HYDRO L.P.	HILLSBOROUGH	PORT SUTTON CHANNEL	PH	SU	MAXIMUM	6/30/2005	5
F0038831	ANASTASIA ISLAND WWTP	ST JOHNS	MATANZAS RV	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	2/28/2005	60
F0038831	ANASTASIA ISLAND WWTP	ST JOHNS	MATANZAS RV	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	3/31/2005	100
F0038831	ANASTASIA ISLAND WWTP	ST JOHNS	MATANZAS RV	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	4/30/2005	40
F0038831	ANASTASIA ISLAND WWTP	ST JOHNS	MATANZAS RV	COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	6/30/2005	110
F0038831	ANASTASIA ISLAND WWTP	ST JOHNS	MATANZAS RV	NITROGEN, KJELDAHL TOTAL	MG/L	MONTHLY AVERAGE	1/31/2005	17
F0038831	ANASTASIA ISLAND WWTP	ST JOHNS	MATANZAS RV	NITROGEN, KJELDAHL TOTAL	MG/L	MAXIMUM	1/31/2005	18
F0038831	ANASTASIA ISLAND WWTP	ST JOHNS	MATANZAS RV	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	3/31/2005	43
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	AMMONIA, UNIONIZED	MG/L	MAXIMUM	3/31/2005	150
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	AMMONIA, UNIONIZED	MG/L	MAXIMUM	7/31/2005	50
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	AMMONIA, UNIONIZED	MG/L	MAXIMUM	10/31/2005	8
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	AMMONIA, UNIONIZED	MG/L	MAXIMUM	11/30/2005	300
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	6/30/2005	50
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	CHLORINE, TOTAL RESIDUAL	MG/L	MAXIMUM	6/30/2005	7100
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	CHLORINE, TOTAL RESIDUAL	MG/L	MAXIMUM	8/31/2005	100
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	8/31/2005	100
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	10/31/2005	100
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	IRON, TOTAL RECOVERABLE	MG/L	MAXIMUM	8/31/2005	3200
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, AMMONIA TOTAL	MG/L	MAXIMUM	3/31/2005	88
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, AMMONIA TOTAL	MG/L	WEEKLY AVERAGE	3/31/2005	151
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, AMMONIA TOTAL	MG/L	MONTHLY AVERAGE	11/30/2005	28
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, AMMONIA TOTAL	MG/L	MAXIMUM	11/30/2005	102
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	1/31/2005	6
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	1/31/2005	27
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	3/31/2005	35
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	MAXIMUM	3/31/2005	97
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	3/31/2005	162
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	MAXIMUM	5/31/2005	61
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	5/31/2005	115
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	6/30/2005	7

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	10/31/2005	19
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	MAXIMUM	10/31/2005	27
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	11/30/2005	9
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	11/30/2005	10
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	MAXIMUM	11/30/2005	26
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	12/31/2005	23
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	MAXIMUM	12/31/2005	86
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	12/31/2005	153
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	PH	SU	MAXIMUM	6/30/2005	15
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	PHOSPHORUS, TOTAL	MG/L	WEEKLY AVERAGE	2/28/2005	32
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	2/28/2005	35
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	PHOSPHORUS, TOTAL	MG/L	WEEKLY AVERAGE	4/30/2005	32
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	4/30/2005	35
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	5/31/2005	100
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	5/31/2005	140
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	PHOSPHORUS, TOTAL	MG/L	WEEKLY AVERAGE	5/31/2005	167
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	6/30/2005	10
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	6/30/2005	45
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	PHOSPHORUS, TOTAL	MG/L	WEEKLY AVERAGE	6/30/2005	94
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	7/31/2005	10
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	SOLIDS, TOTAL SUSPENDED	MG/L	WEEKLY AVERAGE	7/31/2005	47
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	SOLIDS, TOTAL SUSPENDED	MG/L	MONTHLY AVERAGE	8/31/2005	16
F0038857	APALACHICOLA, CITY OF	FRANKLIN	TRIB TO HUCKLEBERRY CR	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	8/31/2005	110
F0039772	W. CARL DICKS WWTP	POLK	LAKELAND DISCHARGE - ALAFIA RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	3/31/2005	*
F0039772	W. CARL DICKS WWTP	POLK	LAKELAND DISCHARGE - ALAFIA RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	4/30/2005	*
F0039772	W. CARL DICKS WWTP	POLK	LAKELAND DISCHARGE - ALAFIA RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	4/30/2005	*
F0039772	W. CARL DICKS WWTP	POLK	LAKELAND DISCHARGE - ALAFIA RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	4/30/2005	*
F0039772	W. CARL DICKS WWTP	POLK	LAKELAND DISCHARGE - ALAFIA RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	6/30/2005	*
F0039772	W. CARL DICKS WWTP	POLK	LAKELAND DISCHARGE - ALAFIA RV	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	9/30/2005	*
F0039829	LEE COUNTY UTIL-FIESTA VILLAGE	LEE	CALOOSAHATCHEE RIVER	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	6/30/2005	42
F0039829	LEE COUNTY UTIL-FIESTA VILLAGE	LEE	CALOOSAHATCHEE RIVER	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	10/31/2005	33
F0040061	PALATKA WWTF	PUTNAM	SAINT JOHNS RIVER	SILVER, TOTAL RECOVERABLE	UG/L	MAXIMUM	10/31/2005	43
F0040061	PALATKA WWTF	PUTNAM	SAINT JOHNS RIVER	SILVER, TOTAL RECOVERABLE	UG/L	MAXIMUM	11/30/2005	27

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F00040061	PALATKA WWTF	PUTNAM	SAINT JOHNS RIVER	SILVER, TOTAL RECOVERABLE	UG/L	MAXIMUM	12/31/2005	57
F00040177	CF INDUSTRIES - HARDEE COMPLEX	HARDEE	SHIRTAIL BR, PAYNE CR, PEACE R	CHLORINE, TOTAL RESIDUAL	MG/L	DAILY MAXIMUM	10/31/2005	800
F00040177	CF INDUSTRIES - HARDEE COMPLEX	HARDEE	SHIRTAIL BR, PAYNE CR, PEACE R	OXYGEN, DISSOLVED	MG/L	DAILY MINIMUM	7/31/2005	2
F00040274	E I DUPONT DE NEOURS - MAXVIL	CLAY	NEW RIVER SWAMP AND GUM BRANCH	FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MGD	DAILY MAXIMUM	7/31/2005	20
F00040274	E I DUPONT DE NEOURS - MAXVIL	CLAY	NEW RIVER SWAMP AND GUM BRANCH	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	7/31/2005	*
F00040274	E I DUPONT DE NEOURS - MAXVIL	CLAY	NEW RIVER SWAMP AND GUM BRANCH	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	8/31/2005	*
F00040274	E I DUPONT DE NEOURS - MAXVIL	CLAY	NEW RIVER SWAMP AND GUM BRANCH	TURBIDITY, LAB, NTU	NTU	MAXIMUM	7/31/2005	206
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	WEEKLY AVERAGE	5/31/2005	23
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	NITROGEN, AMMONIA TOTAL	MG/L	MAXIMUM	8/31/2005	17
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	NITROGEN, AMMONIA TOTAL	MG/L	WEEKLY AVERAGE	8/31/2005	57
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	NITROGEN, ORGANIC TOTAL	MG/L	MONTHLY AVERAGE	2/28/2005	12
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	NITROGEN, ORGANIC TOTAL	MG/L	MAXIMUM	2/28/2005	81
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	NITROGEN, ORGANIC TOTAL	MG/L	WEEKLY AVERAGE	2/28/2005	142
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	NITROGEN, ORGANIC TOTAL	MG/L	MONTHLY AVERAGE	8/31/2005	145
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	NITROGEN, ORGANIC TOTAL	MG/L	MAXIMUM	8/31/2005	575
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	NITROGEN, ORGANIC TOTAL	MG/L	WEEKLY AVERAGE	8/31/2005	800
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	NITROGEN, ORGANIC TOTAL	MG/L	MAXIMUM	10/31/2005	40
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	NITROGEN, ORGANIC TOTAL	MG/L	WEEKLY AVERAGE	10/31/2005	87
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	NITROGEN, ORGANIC TOTAL	MG/L	WEEKLY AVERAGE	11/30/2005	7
F00040495	MACCLENNY WTP	BAKER	ST MARYS RIVER VIA TURKEY CREEK	SOLIDS, TOTAL SUSPENDED	MG/L	WEEKLY AVERAGE	5/31/2005	9
F00040614	HILLSBORO CO - FALKENBURG	HILLSBOROUGH	PALM RIVER	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	1/31/2005	10
F00040614	HILLSBORO CO - FALKENBURG	HILLSBOROUGH	PALM RIVER	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	12/31/2005	40
F00040665	CLEWISTON WW DEPT	HENDRY	LAT #9 SUGARLAND AND CALOOSAHATCHEE	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	10/31/2005	82
F00040771	SARASOTA CITY OF WWTP	SARASOTA	WHITAKER BAYOU	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	9/30/2005	2
F00040771	SARASOTA CITY OF WWTP	SARASOTA	WHITAKER BAYOU	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	9/30/2005	21
F00040771	SARASOTA CITY OF WWTP	SARASOTA	WHITAKER BAYOU	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	10/31/2005	10
F00040771	SARASOTA CITY OF WWTP	SARASOTA	WHITAKER BAYOU	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	10/31/2005	31
F00040771	SARASOTA CITY OF WWTP	SARASOTA	WHITAKER BAYOU	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	1/31/2005	*
F00040771	SARASOTA CITY OF WWTP	SARASOTA	WHITAKER BAYOU	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	5/31/2005	*
F00040771	SARASOTA CITY OF WWTP	SARASOTA	WHITAKER BAYOU	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	6/30/2005	*
F00040771	SARASOTA CITY OF WWTP	SARASOTA	WHITAKER BAYOU	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	11/30/2005	50
F00040771	SARASOTA CITY OF WWTP	SARASOTA	WHITAKER BAYOU	NOEL STATRE 7DAY CHR CERIODAPHNIA	PERCENT	MINIMUM	11/30/2005	50
F00040771	SARASOTA CITY OF WWTP	SARASOTA	WHITAKER BAYOU	PH	SU	MINIMUM	8/31/2005	9

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F00040983	HILLSBOROUGH CITY VALRICO WWTP	HILLSBOROUGH	TO TURKEY CREEK, ALAFIA, TAMPA BAY	NITROGEN, TOTAL	MG/L	MAXIMUM	9/30/2005	37
F00040983	HILLSBOROUGH CITY VALRICO WWTP	HILLSBOROUGH	TO TURKEY CREEK, ALAFIA, TAMPA BAY	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	9/30/2005	43
F00040983	HILLSBOROUGH CITY VALRICO WWTP	HILLSBOROUGH	TO TURKEY CREEK, ALAFIA, TAMPA BAY	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	10/31/2005	24
F00040983	HILLSBOROUGH CITY VALRICO WWTP	HILLSBOROUGH	TO TURKEY CREEK, ALAFIA, TAMPA BAY	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	11/30/2005	3
F00040983	HILLSBOROUGH CITY VALRICO WWTP	HILLSBOROUGH	TO TURKEY CREEK, ALAFIA, TAMPA BAY	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	11/30/2005	29
F00040983	HILLSBOROUGH CITY VALRICO WWTP	HILLSBOROUGH	TO TURKEY CREEK, ALAFIA, TAMPA BAY	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	12/31/2005	3
F00040983	HILLSBOROUGH CITY VALRICO WWTP	HILLSBOROUGH	TO TURKEY CREEK, ALAFIA, TAMPA BAY	PH	SU	DAILY MINIMUM	2/28/2005	4
F00040983	HILLSBOROUGH CITY VALRICO WWTP	HILLSBOROUGH	TO TURKEY CREEK, ALAFIA, TAMPA BAY	PH	SU	DAILY MINIMUM	3/31/2005	2
F00041441	VENICE - EASTSIDE WWTP	SARASOTA	CURRY CREEK	CHLORINE, TOTAL RESIDUAL	MG/L	DAILY MINIMUM	7/31/2005	30
F00041637	INDIAN RIV CITY-WEST REGIONAL	INDIAN RIVER	SOUTH RELIEF CANAL	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	5/31/2005	17
F00041637	INDIAN RIV CITY-WEST REGIONAL	INDIAN RIVER	SOUTH RELIEF CANAL	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MONTHLY AVERAGE	8/31/2005	2
F00041637	INDIAN RIV CITY-WEST REGIONAL	INDIAN RIVER	SOUTH RELIEF CANAL	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	8/31/2005	17
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	1/31/2005	33
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	1/31/2005	39
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	1/31/2005	57
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	2/28/2005	58
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	2/28/2005	58
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	2/28/2005	74
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	3/31/2005	7
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	3/31/2005	109
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	3/31/2005	150
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	3/31/2005	173
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	4/30/2005	20
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	4/30/2005	103
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	DAILY MAXIMUM	4/30/2005	262
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	WEEKLY AVERAGE	4/30/2005	298
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	5/31/2005	20
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	6/30/2005	24
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	7/31/2005	29
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	8/31/2005	31
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	9/30/2005	32
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	10/31/2005	33
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	11/30/2005	30

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	NITROGEN, TOTAL	MG/L	ANNUAL AVERAGE	12/31/2005	27
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	PHOSPHORUS, TOTAL	MG/L	MAXIMUM	4/30/2005	65
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	PHOSPHORUS, TOTAL	MG/L	WEEKLY AVERAGE	4/30/2005	93
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	SOLIDS, TOTAL SUSPENDED	MG/L	DAILY MAXIMUM	4/30/2005	46
F00041670	NORTHWEST REGIONAL WRF	HILLSBOROUGH	CHANNEL A, ROCKY CREEK, OLD TAMPA B	SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	8/31/2005	52
F00041751	HARDEE POWER STA-TECO PWR STA	HARDEE	PAYNE CREEK	PH	SU	MINIMUM	9/30/2005	43
F00041751	HARDEE POWER STA-TECO PWR STA	HARDEE	PAYNE CREEK	TEMPERATURE, WATER DEG. F	DEG.F	INSTANTANEOUS MAXIMUM	8/31/2005	2
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	9/30/2005	40
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	10/31/2005	60
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	11/30/2005	60
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	CHLORINE, TOTAL RESIDUAL	MG/L	MINIMUM	12/31/2005	70
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	8/31/2005	133
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	9/30/2005	121
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	DICHLOROBROMOMETHANE	UG/L	MAXIMUM	8/31/2005	64
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	DICHLOROBROMOMETHANE	UG/L	MAXIMUM	9/30/2005	132
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	DICHLOROBROMOMETHANE	UG/L	MAXIMUM	10/31/2005	5
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	DICHLOROBROMOMETHANE	UG/L	MAXIMUM	11/30/2005	32
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	DICHLOROBROMOMETHANE	UG/L	MAXIMUM	12/31/2005	12
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	9/30/2005	30
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	10/31/2005	20
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	PHENOLIC COMPOUNDS, TOTAL	UG/L	MAXIMUM	11/30/2005	100
F00042625	SEMINOLE CTY DEPT OF EVO SRV	SEMINOLE	ST. JOHNS RIVERS	SILVER, TOTAL RECOVERABLE	UG/L	MAXIMUM	12/31/2005	3871
F00043869	TAMPA ELEC-POLK POWER STATION	POLK	LITTLE PAYNE CREEK	ALPHA, GROSS PARTICLE ACTIVITY	PCI/L	MAXIMUM	12/31/2005	4
F00043869	TAMPA ELEC-POLK POWER STATION	POLK	LITTLE PAYNE CREEK	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	DAILY MAXIMUM	12/31/2005	182
F00043869	TAMPA ELEC-POLK POWER STATION	POLK	LITTLE PAYNE CREEK	SOLIDS, TOTAL SUSPENDED	MG/L	DAILY AVERAGE	2/28/2005	163
F00044229	SEMINOLE ELEC.- HARDEE UNIT 3	HARDEE	PAYNE CREEK	TEMPERATURE, WATER DEG. F	DEG.F	INSTANTANEOUS MAXIMUM	8/31/2005	2
F0103349	CITY OF TITUSVILLE-BLUE HERON	BREVARD		PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	10/31/2005	30
F0103349	CITY OF TITUSVILLE-BLUE HERON	BREVARD		PHOSPHORUS, TOTAL	MG/L	MAXIMUM	10/31/2005	169
F0103349	CITY OF TITUSVILLE-BLUE HERON	BREVARD		PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	11/30/2005	20
F0103349	CITY OF TITUSVILLE-BLUE HERON	BREVARD		PHOSPHORUS, TOTAL	MG/L	MAXIMUM	11/30/2005	78
F0103349	CITY OF TITUSVILLE-BLUE HERON	BREVARD		SOLIDS, TOTAL SUSPENDED	MG/L	MONTHLY AVERAGE	2/28/2005	31
F0103349	CITY OF TITUSVILLE-BLUE HERON	BREVARD		SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	2/28/2005	117
F0128937	CLEARWATER CITY OF NORTHEAST	PINELLAS		COLIFORM, FECAL MF, M-FC BROTH, 44.5C	#/100ML	MAXIMUM	1/31/2005	1216

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
FLO128937	CLEARWATER CITY OF NORTHEAST	PINELLAS		COLIFORM, FECAL MF, M-FC BROTH, 44.5C	#/100ML	MAXIMUM	4/30/2005	300
FLO128937	CLEARWATER CITY OF NORTHEAST	PINELLAS		COLIFORM, FECAL MF, M-FC BROTH, 44.5C	#/100ML	MAXIMUM	5/31/2005	300
FLO128937	CLEARWATER CITY OF NORTHEAST	PINELLAS		COPPER, TOTAL RECOVERABLE	UG/L	MAXIMUM	2/28/2005	69
FLO167959	BAY CTY. - MILITARY PT. AWT	BAY		NOEL STAITRE 7DAY CHR PIPEPHALES	PERCENT	MINIMUM	12/31/2005	*
FLO167959	BAY CTY. - MILITARY PT. AWT	BAY		NOEL STAITRE 7DAY CHR PIPEPHALES	PERCENT	MINIMUM	12/31/2005	*
FLO167959	BAY CTY. - MILITARY PT. AWT	BAY		ULTRAVIOLET LIGHT DOSAGE	UWS/CM2	MINIMUM	6/30/2005	100
FLO169978	CITY OF LYNN HAVEN	BAY		COLIFORM, FECAL GENERAL	#/100ML	MONTHLY MEDIAN	11/30/2005	22
FLO169978	CITY OF LYNN HAVEN	BAY		COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	11/30/2005	98
FLO169978	CITY OF LYNN HAVEN	BAY		COPPER, TOTAL	UG/L	MAXIMUM	6/30/2005	21
FLO169978	CITY OF LYNN HAVEN	BAY		COPPER, TOTAL	UG/L	MAXIMUM	12/31/2005	1486
FLO169978	CITY OF LYNN HAVEN	BAY		NOEL STAITRE 7DAY CHR PIPEPHALES	PERCENT	MINIMUM	5/31/2005	*
FLO169978	CITY OF LYNN HAVEN	BAY		PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	4/30/2005	29
FLO169978	CITY OF LYNN HAVEN	BAY		PHOSPHORUS, TOTAL	MG/L	MAXIMUM	7/31/2005	38
FLO169978	CITY OF LYNN HAVEN	BAY		PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	7/31/2005	52
FLO169978	CITY OF LYNN HAVEN	BAY		SOLIDS, TOTAL SUSPENDED	MG/L	MAXIMUM	11/30/2005	49
FLO169978	CITY OF LYNN HAVEN	BAY		ULTRAVIOLET LIGHT INTENSITY	MW/CM2	MINIMUM	11/30/2005	25
FLO169978	CITY OF LYNN HAVEN	BAY		ULTRAVIOLET LIGHT INTENSITY	MW/CM2	MINIMUM	11/30/2005	32
FLO169978	CITY OF LYNN HAVEN	BAY		ZINC, TOTAL RECOVERABLE	UG/L	MAXIMUM	12/31/2005	17
FLO170909	THE MILLVILLE WWT FACILITY	BAY		COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	4/30/2005	78
FLO170909	THE MILLVILLE WWT FACILITY	BAY		COLIFORM, FECAL GENERAL	#/100ML	90TH PERCENTILE	4/30/2005	133
FLO170909	THE MILLVILLE WWT FACILITY	BAY		COLIFORM, FECAL GENERAL	#/100ML	MAXIMUM	6/30/2005	121
FLO170909	THE MILLVILLE WWT FACILITY	BAY		PHOSPHORUS, TOTAL	MG/L	MAXIMUM	6/30/2005	175
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	1/31/2005	36
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	11/30/2005	109
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	12/31/2005	81
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	1/31/2005	115
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	2/28/2005	77
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	3/31/2005	139
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	4/30/2005	145
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	5/31/2005	119
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	6/30/2005	129
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	7/31/2005	126
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		DICHLOROBROMOMETHANE	UG/L	ANNUAL AVERAGE	8/31/2005	101

Facility Number	Facility Name	County	Receiving Water	Parameter Description	Unit	Permit Description	Report Period End Date	Percent Exceedance
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		PHOSPHORUS, TOTAL	MG/L	MAXIMUM	8/31/2005	44
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		PHOSPHORUS, TOTAL	MG/L	WEEKLY AVERAGE	8/31/2005	91
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		PHOSPHORUS, TOTAL	MG/L	MONTHLY AVERAGE	8/31/2005	94
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		PHOSPHORUS, TOTAL	MG/L	MAXIMUM	9/30/2005	1
FLO172090	NEW SMYRNA BEACH AWT FACILITY	VOLUSIA		PHOSPHORUS, TOTAL	MG/L	WEEKLY AVERAGE	9/30/2005	31
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MAXIMUM	12/31/2005	10
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	BOD, CARBONACEOUS 5 DAY, 20 DEG. C	MG/L	MONTHLY AVERAGE	12/31/2005	32
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	NITROGEN, AMMONIA TOTAL	MG/L	MONTHLY AVERAGE	2/28/2005	15
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	NITROGEN, AMMONIA TOTAL	MG/L	MAXIMUM	4/30/2005	3
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	NITROGEN, AMMONIA TOTAL	MG/L	MONTHLY AVERAGE	4/30/2005	65
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	NITROGEN, AMMONIA TOTAL	MG/L	MONTHLY AVERAGE	4/30/2005	90
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	NITROGEN, AMMONIA TOTAL	MG/L	MAXIMUM	4/30/2005	275
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	1/31/2005	5
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	NITROGEN, TOTAL	MG/L	MONTHLY AVERAGE	4/30/2005	21
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	NITROGEN, TOTAL	MG/L	MAXIMUM	4/30/2005	78
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	1/31/2005	66
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	2/28/2005	66
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	3/31/2005	52
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	4/30/2005	2
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	5/31/2005	2
FLO173371	SPENCER'S WWTP	CLAY	SPENCER WETLAND	SOLIDS, TOTAL SUSPENDED	MG/L	ANNUAL AVERAGE	6/30/2005	2
FLO186813	TAMPA BAY DESAL	HILLSBOROUGH		NOEL STATRE 7DAY CHR MENIDIA	PERCENT	MINIMUM	10/31/2005	*
FLO186813	TAMPA BAY DESAL	HILLSBOROUGH		PH	SU	DAILY MAXIMUM	10/31/2005	7
FLO186813	TAMPA BAY DESAL	HILLSBOROUGH		PH	SU	DAILY MINIMUM	10/31/2005	8
FLO186813	TAMPA BAY DESAL	HILLSBOROUGH		PH	SU	DAILY MINIMUM	11/30/2005	3

* Signifies an apparent exceedance of undetermined magnitude

Unit Key: Common Acronyms and Abbreviations		Unit	Full Phrase	Unit	Full Phrase
#/100ML	NUMBER PER 100 MILLILITERS	GR/DAY	GRAMS PER DAY	MPN/100ML	MOST PROBABLE NUMBER PER 100 MILLILITERS
ACUTE TOXICITY	ACUTE TOXICITY	KG/DAY	KILOGRAMS PER DAY	NG/L	NANOGRAMS PER LITER
CFU/100ML	COLONY FORMING UNITS PER 100 MILLILITERS	LBS/DAY	POUNDS PER DAY	NTU	NEPHELOMETRIC TURBIDITY UNITS
CHRONIC TOXICITY	CHRONIC TOXICITY	MG/L	MILLOGRAMS PER LITER	OCCUR/MONTH	OCCURRENCES PER MONTH
DEG.F	DEGREES FAHRENHEIT	MGD	MILLION GALLONS PER DAY	SU	STANDARD UNITS
GPM	GALLONS PER MINUTE	M/L	MILLILITERS PER LITER	UG/L	MICROGRAMS PER LITER